

25-4091

From WMIS:

E 0007151

STANDBY WELL

P/D N 271905.30

50 HP

E 667470.10

Pump has not been used for over 12 years, except for 10 or 15 minute tests twice a year to keep it in working order. Designed to pump 600 GPM.

10/7/2003

Ross said they may run it on Friday, if so he would call me to take a measurement. Requested EOP and map of service area. Left EOP brochure.

$$Q = \frac{(50 \text{ HP})(8.814)(0.70)}{110' + (2.31 \times 65 \text{ psi})} = 1.19 \text{ cfs}$$