

# Memo

**To:** file 25-11143  
**From:** Roger Warner *[Signature]*  
**CC:**  
**Date:** 7/17/2003  
**Re:** sonic meter analysis of diversion

---

I visited the site this morning at about 10:00 am. Claimant, Craig Hart accompanied me to an area where a good strait length of pipe was found for measurement. This was at the back of the plant near the flume where potatoes are received.

Upon equipment preparation, the processing began and all appropriate water hoses were turned on. The meter, when flows stabilized, read consistently at 90 gallons per minute.

Since the claimant indicates that the pump was recently replaced, it is assumed that the system is near optimum in capacity. Therefore, the amount of 90 gallons per minute (converted to cfs) will be recommended for their water right.