

RECOMMENDED POINT(S) OF DIVERSION AND SOURCE:
IMP. RSE. SEC. 1/4 1/4 LOT 1/4 COUNTY DIVERSION NAME

SOURCE: GROUNDWATER

TRIG:

REVIEWED BY:

DC

DATE:

5/3/95


SYSTEM DESCRIPTION:

US MOTOR, 150HP, # 7945415 Same motor as 1955 licensing NORTH ↑
exam.

PUMP: W/THROAT - 14" DISCHARGE

ESTIMATE DEPTH TO WATER 2150'

COUNTY LOCATION # 549



$$\frac{150hp}{135' DP}$$

open discharge

$$CFS = \frac{(616)(150hp)}{135'} = 6.84 CFS$$

