

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
ADJUDICATION SECTION
CLAIM VERIFICATION FIELD EXAM SHEET
(Use with the ECVR)**

CLAIM NO(s). 75-7031

1. ☐ No Change NAME IS SAME
☒ NEW OWNER: Clyde L. Phillips
☐ No Change ADDRESS
☒ NEW ADDRESS: 12 Hussey Ln Salmon ID 83467
2. ☐ No Change - DATE OF PRIORITY: Completed evidence submitted
☐ Incomplete - Claimant should be asked during the exam when was water first used and submit proof of date of priority.

Priority date, per claimant, is: _____
(If the priority date, based on your exam, seems questionable, explain below.)

3. ☒ No Change — SAME SOURCE
☐ Source is different than that claimed:
Source found: _____

4. ☐ No Change — POINT OF DIVERSION
☒ Point of diversion is different than the claim and/or new P/D's:
GPS Site Tag No.: No tag, STC-04 on map
Township 18N Range 21E Section 8 1/4 SE 1/4 SE 1/4 SE
Township _____ Range _____ Section _____ 1/4 1/4 1/4

5. ☒ No Change - DESCRIPTION OF DIVERTING WORKS
☐ Incomplete description, list below:
dam in creek ditch to place of use

6. ☒ No Change - WATER USES
☐ Different uses, (list uses found):

Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____

7. ☒ No Change - TOTAL VOLUME

☐ Incomplete on claim, the total is, Amount _____ CFS _____ AFA

☐ Changes found, the new total is, Amount _____ CFS _____ AFA

8. ☐ No Change - NON-IRRIGATION USES:

☐ Changes Exam found:

Domestic # of homes: _____ Stock # _____ List types: _____

Additional comments: _____

9. ☐ No Change — PLACE OF USE: (If changed, list below.)

Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____

Remarks: (Comments pertinent to field examination) ☐ See additional attachment

☐ SYSTEM DIAGRAM INCLUDED

☐ NA

☒ Shown on GIS Layout

☐ CK IF IN OFFICE EXAM

DATE EXAM CONDUCTED: 8-17-05

FIELD EXAMINER:

Bob Foster

Print Name

Bob Foster

Signature

New ditch

File IRON CREEK 4

Start Date and Time ----- 2004/06/02 11:12:34
 Sensor Type ----- FlowTracker Handheld ADV
 SerialNumber ----- P170
 Averaging Time ----- 20 sec
 Units system ----- ENGLISH
 Staff height ----- 0.00 ft
 Gauge height ----- 0.00 ft
 Rated discharge ----- 0.000 cfs
 Starting edge of water ---- LEW
 Number of stations ----- 10
 Total width ----- 4.4 ft
 Total area ----- 3.56 ft^2
 Total discharge ----- 5.562 cfs
 Mean velocity ----- 1.602 ft/s
 Mean SNR ----- 24.7 dB
 Mean std. error of vel. -- 0.05 ft/s
 Mean boundary conditions -- 0 (BEST)
 Boundary condition (Bnd) -- 0: BEST

- 1: GOOD
- 2: FAIR
- 3: POOR

done

$$\begin{array}{r} 5.502 \\ 2.390 \\ \hline 2 \end{array}$$

ST.	Loc.	Depth	IceD	MDep	Clock	Npts	Spike	Vel	SNR	Angle	Verr	Bnd	Temp	Corr	MeanV	Area	Flow
	(ft)	(ft)	(ft)	(*D)	(ft/s)	(dB)	(deg)	(ft/s)	(degF)	Fact	(ft/s)	(ft^2)	(cfs)				
0	1.0	0.00	0.00	.0	00:00	0	0	0.00	0.0	0	0.0	0	0.00	1.00	1.170	0.00	0.000
1	1.4	0.20	0.00	.6	11:12	20	0	1.170	24.9	5	0.03	0	46.31	1.00	1.170	0.080	0.093
2	1.8	0.35	0.00	.6	11:13	20	0	1.641	24.9	6	0.05	0	46.17	1.00	1.641	0.140	0.229
3	2.2	0.50	0.00	.6	11:14	20	0	2.130	25.3	6	0.06	0	46.15	1.00	2.130	0.200	0.426
4	2.6	0.70	0.00	.6	11:14	20	0	2.348	24.9	6	0.03	0	46.15	1.00	2.348	0.280	0.657
5	3.0	1.00	0.00	.6	11:15	20	1	2.186	24.9	12	0.04	0	46.13	1.00	2.186	0.400	0.874
6	3.4	1.15	0.00	.6	11:16	20	1	1.976	24.9	16	0.06	0	46.15	1.00	1.976	0.460	0.909
7	3.8	1.30	0.00	.6	11:17	20	1	1.816	24.9	8	0.07	0	46.17	1.00	1.816	0.520	0.944
8	4.2	1.30	0.00	.6	11:17	20	0	1.635	24.0	9	0.05	0	46.17	1.00	1.635	0.520	0.850
9	4.6	1.30	0.00	.6	11:18	20	0	1.082	24.0	13	0.07	0	46.18	1.00	1.082	0.520	0.563
10	5.0	1.10	0.00	.6	11:19	20	1	0.035	24.5	84	0.04	2	46.20	1.00	0.035	0.440	0.015
11	5.4	0.00	0.00	.0	00:00	0	0	0.00	0.0	0	0.0	0	0.00	1.00	0.035	0.00	0.000