

29-10029

5/29/02

Portneuf River

Looking N.



River Pump is Used 3 or 4 months out of the year

Tsurumi

5 HP Sub Pump

Rated to Run 150 GPM

Claimant Figures 132 GPM

Flow meter Estimates 100 GPM