

STATE OF IDAHO
DEPARTMENT OF HEALTH
LABORATORIES

POCATELLO
TWIN FALLS

BOISE

COEUR D'ALENE
LEWISTON

REPORT OF WATER ANALYSIS

May 14, 1963

Name Blackfoot City

Address City Hall, Blackfoot, Idaho

Source City Golf Course

Date Collected 5-8-63 Date Received 5-10-63

RESULT:

Intestinal bacteria were Not found in this sample of water.

J. H. Frazier
Microbiologist

EXPLANATION: Intestinal bacteria **should not be found** in your water supply. The presence of these organisms indicates that your water is **contaminated**. This may be due either to poor quality of water at its source or improper construction and maintenance of the system. Because the quality of water may vary from time to time, it is recommended that repeat samples be submitted. For Department of Health recommendations or approval of your water supply, please contact your sanitarian or public health engineer.

Form DH 59006

MICROFILMED
NOV 13 1995