

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
ADJUDICATION SECTION
CLAIM VERIFICATION FIELD EXAM SHEET
(Use with the ECVR)

CLAIM NO(s). 75-10075

1. ☒ No Change NAME IS SAME
☐ NEW OWNER: _____
☐ No Change ADDRESS
☐ NEW ADDRESS: _____

2. ☒ No Change - DATE OF PRIORITY: Completed evidence submitted
☐ Incomplete - Claimant should be asked during the exam when was water first used and submit proof of date of priority.

Priority date, per claimant, is: _____
(If the priority date, based on your exam, seems questionable, explain below.)

3. ☒ No Change — SAME SOURCE
☐ Source is different than that claimed:

Source found: _____

4. ☐ No Change — POINT OF DIVERSION
☒ Point of diversion is different than the claim and/or new P/D's:

GPS Site Tag No.: A0014950 Pollard Creek A0014948 Chipps Creek

Township 21N Range 21E Section 11 1/4 NW 1/4 NW 1/4 NW Chipps Creek
Township 21N Range 21E Section 2 1/4 SW 1/4 SW 1/4 SW Pollard Creek

5. ☒ No Change - DESCRIPTION OF DIVERTING WORKS
☐ Incomplete description, list below:

Concrete headgate in creek pipeline to treatment plant

6. ☒ No Change - WATER USES
☐ Different uses, (list uses found):

Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____

7. ☒ No Change - TOTAL VOLUME

☐ Incomplete on claim, the total is, Amount _____ CFS _____ AFA

☐ Changes found, the new total is, Amount _____ CFS _____ AFA

8. ☐ No Change - NON-IRRIGATION USES:

☐ Changes Exam found:

Domestic # of homes: _____ Stock # _____ List types: _____

Additional comments: _____

9. ☒ No Change — PLACE OF USE: (If changed, list below.)

Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____

Remarks: (Comments pertinent to field examination) ☐ See additional attachment

per is City of Salem. a 1/4 mile 12" line carries Chipps Cr. to
Pollard Cr. a 14" 1.5 mile pipeline carries Chipps + Pollard Cr.
water to Jesse Cr. where a 14" 1/2 mile pipeline carries combined water
to treatment plant

☒ SYSTEM DIAGRAM INCLUDED ☐ NA

☐ Shown on GIS Layout

☐ CK IF IN OFFICE EXAM

DATE EXAM CONDUCTED: 4-19-06

FIELD EXAMINER: Bob Foster
Print Name

Bob Foster
Signature

KSCRC

POD GR 75-10075

CHIPS CREER

TREATMENT PLAN

NO POD here
Part of DIVERSION
FORWARD CREEK

$$\frac{m_2 r}{m_1 r}$$
 $R^{22}E$

Point of Diversion
from River

T221

721A