

75-14302
75-14303

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
ADJUDICATION SECTION
CLAIM VERIFICATION FIELD EXAM SHEET
(Use with the ECVR)**

CLAIM NO(s). 75-4385C

1. ☒ No Change NAME IS SAME
☐ NEW OWNER: _____
☒ No Change ADDRESS
☐ NEW ADDRESS: _____
2. ☐ No Change - DATE OF PRIORITY: Completed evidence submitted
☐ Incomplete - Claimant should be asked during the exam when was water first used and submit proof of date of priority.

Priority date, per claimant, is: _____
(If the priority date, based on your exam, seems questionable, explain below.)

3. ☒ No Change — SAME SOURCE
☐ Source is different than that claimed:

Source found: _____

4. ☒ No Change — POINT OF DIVERSION
☐ Point of diversion is different than the claim and/or new P/D's:
GPS Site Tag No.: A0015060 F.6 " W62405 P001

Township 22N Range 22E Section 1 1/4 NE 1/4 NE 1/4 SW
Township _____ Range _____ Section _____ 1/4 _____ 1/4 _____ 1/4 _____

5. ☐ No Change - DESCRIPTION OF DIVERTING WORKS
☒ Incomplete description, list below:

headgate with open ditch to pipeline for GRAVITY sprinkler system

assessor's office 2 parcels 22 & 6.2

28 acres x 0.02 cfs = 0.56 cfs

6. ☒ No Change - WATER USES
☐ Different uses, (list uses found):

Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____
Use _____	From _____	To _____	Amount _____	CFS _____	AFA _____

7. ☒ No Change - TOTAL VOLUME *See Remarks*

☐ Incomplete on claim, the total is, Amount _____ CFS _____ AFA

☐ Changes found, the new total is, Amount _____ CFS _____ AFA

8. ☐ No Change - NON-IRRIGATION USES:

☐ Changes Exam found:

Domestic # of homes: _____ Stock # _____ List types: _____

Additional comments: _____

9. ☐ No Change — PLACE OF USE: (If changed, list below.)

Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____
Use: _____	Township _____	Range _____	Section _____	1/4 _____	1/4 _____

Remarks: (Comments pertinent to field examination) ☐ See additional attachment

*System consists of gravity fed sprinkler system that runs
15 9/64 rainbirds at an estimated 40 psi = 56 gpm = .12 cfs. Reading
on a 1.5' Cipolletti Wier at pond was .3 on wier crest = .63 cfs*

75-4385C & D same POP

☐ SYSTEM DIAGRAM INCLUDED ☐ NA

☒ Shown on GIS Layout

☐ CK IF IN OFFICE EXAM

DATE EXAM CONDUCTED: *6-30-05*

FIELD EXAMINER: *Bob Foster*
Print Name

Bob Foster
Signature