

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources, within 30 days after the completion or abandonment of the well.

days after the completion or abandonment of the well.


WELL OWNER
Name CITY OF WEISER
Address 55 WEST IDAHO ST. WEISER, IDAHO 83672
Owner's Permit No. _____

NATURE OF WORK
☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type) _____
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

METHOD DRILLED
☐ Cable ☒ Rotary ☐ Dug ☐ Other _____

WELL CONSTRUCTION
Diameter of hole 6 inches Total depth 206 feet
Casing schedule: ☒ Steel ☐ Concrete
Thickness Diameter From To
250 inches 6 inches + 1 feet 331 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☒ Knife ☐ Torch
Size of perforation 1/8 inches by 3 inches
Number From To
20 perforations 25 feet 27 feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter Slot size Set from feet to feet
Diameter Slot size Set from feet to feet
Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from feet to feet
Surface seal depth 18 Material used in seal ☒ Cement grout
☐ Pudding clay ☐ Well cuttings
Sealing procedure used ☐ Sherry pit ☒ Temporary surface casing
☐ Overbore to seal depth

LOCATION OF WELL
Sketch map location must agree with written location.

Subdivision Name AIRPORT ROAD
Lot No. _____ Block No. _____
County WASHINGTON

WATER LEVEL
Static water level 7 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature 60° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

WELL TEST DATA
☐ Pump ☒ Bailor ☐ Other _____
Discharge G.P.M. Draw Down Hours Pumped
20 18 1

LITHOLOGIC LOG
Hole Diam. Depth Material Water Yes No
6 0 2 Top Soil X
2 9 Brown Clay X
9 21 Medium Brown Sand X
21 28 Medium Gravel & Coarse
Gray Sand X
28 206 Blue Clay X

DRILLERS CERTIFICATION
Firm Name PAGE BROTHERS DRILLING Firm No. 225
Address RT 2 BOX 371 VALE, ORE Date 10/2/80
Signed by (Firm Official) [Signature]
and
(Operator) [Signature]

Work started 9/30/80 finished 9/30/80

NW ¼ NE ¼ Sec. 17 T. 10S N.S.R. 5W E/W

SCANNED
APR 11 2008