

RECOMMENDATION REVIEW:

Date: 10/27/2008
Agent: S. Hemenway
Claimant: City of Garden City, Public Works Dept.
Garden City Contact: Larry Bybee (208) 375-3194
Engineering Contact: Cathy Cooper @SPF Engineering (208) 383-4140
WR# 63-8357
Mailing Address: 6015 Glenwood, Garden City, ID 83714
Phone #: (208) 472-2930
Attorney Representing Claimant: Frank Walker
Attorney's Address: 6015 Glenwood, Garden City, ID 83714
Attorney's Phone#: (208)472-2912
Location of POD: T4N R1E SEC 25 SWNW
Measuring Device: spurling #76676 flow meter
System: 324' deep well, pump set at 150 ft., 40 Hp Jacuzzi, 8,000 gallon holding tank. System is also connected to the main water system of "Boise Water Corp." 530 gpm.(now the City of Garden City) per 3/3/1982 FE notes. 12" ductile iron pipe to 12" thru 4" cast iron, PVC, and steel distribution line (additional notes from 6/8/2004 DEQ inspection notes).
Field Exam: 3/3/1982 calculated the **capacity of the system to be 1.18 cfs, 258.0 af**
Nonirrigation Uses: Originally listed as for domestic for 215 homes in Millstream Subdivision, but this is an interconnected looped Municipal water system that has multiple wells that work throughout system on demand. Amended claim, and changed Domestic to Municipal.
Other Uses: NONE
Other WRs Used: other licenses that overlap Sec. 25 and Sec. 26: 63-3124, 63-2872, 63-2895, 63-7805, 63-8005, 63-9134 and 63-9136 This is an interconnected looped Municipal water system.
Basis of Claim: License

***This License states Basis of Claim as "Domestic for 215 units" which is unlike all other Licenses listed for the City of Garden City, which state basis as "Municipal." This system first belonged to Boise Water Corporation (United Water), & was purchased on 10/12/1977, but in 2003 they forfeited their claim for this WR, which lead up to the City of Garden City filing a late claim on this water right.

Priority Date: 8/16/1976
Evidence of Priority: 8/13/1976 Water Permit Filing Fee receipt; Notice of Application for Water Permit published in the Idaho Statesman
1/26/1977 completion date on Well Driller's Report.
NOTES: This Public Drinking Water System is regulated by DEQ Water Quality Dept. PWS#4010066.
8/18/1981 letter from Leavitt NuPacific, Peg Wiley, stated that project had been completed &

NOTES: (continued)

well and appurtenances had been turned over to Boise Water Corp 10/12/1977.
(copy of Bargain and Sale Deed are in the file, dated 10/12/1977)

9/30/08 I spoke with Carter Fritschle and he said to contact the attorney and find out if they would like to amend this claim in order to correct the QQ that does not match the License, change Domestic to Municipal since well #12 is interconnected to the entire PWS system (per Larry Bybee, PWS Director at the City of Garden City 375-3194). This would be an Accomplished Transfer from "Domestic" to "Municipal" use. The POU will match the other licenses that overlap and service the area of the City of Garden City, and there will be no "AF" listed, only 1.18cfs for 63-8357.

6/8/2004 Sanitary Survey conducted by the Dept. of Environmental Quality (DEQ) on City of Garden City, confirmed well #12 is a "combined source" within the Community Water System, and that it is a "Municipal Service Category." Certified Operator: Larry Bybee.

9/30/2008 I spoke with Larry Bybee, and well #12 is not a primary well for the City of Garden City water system. This has been a looped system, interconnected with the entire City of Garden City's water system ever since UWI bought the system (1977).

10/7/2008 I spoke with Frank Walker, Attorney for City of Garden City, and he agreed that this claim should be amended from being a "Domestic" claim to a "Municipal" claim; to include POU as the entire Garden City service area to match other Licenses, since this is an interconnected looped water system.

Changes with amended claim:

Purpose would be Municipal instead of Domestic

POU would be Municipal instead of Millstream Subdivision (would include entire map serviced by City of Garden City)

Diversion Rate would stay the same: 1.18 cfs

Annual Volume of 258.0 would be left blank (to match how the other licenses were recommended).

This would correct the data entry error for Sec 26 NWSE which should have been Sec. NESE (to match License)

Recommendation:

C18

124 POU w/in the service area of City of Garden City municipal water supply.

FE 3/3/1982 530 gpm X 0.00223 = 1.18 cfs

C04 Accomplished change of purpose (changed from Domestic to Municipal)

Explanatory: Common name for Point of Diversion is Well #12 Millstream.

Explanatory: DEQ Tag ID# E0006307.

C05 Accomplished change in POU (interlooped Municipal system)