

RESUBMITTED
2-9-2009
J. BARTON

Receipt No: N000205

Date: 06/08/88
Time: 08:07:03

Received
From: GARY BARTON

Type of Payment	Program A cct	Amount
WELL DRILLING PERMIT	0650350 1238 6390	\$10.00

Total \$10.00

CASH

Idaho Department of Water Resources

Region: Northern

Signature:

004008

AAA

S. 17 WILLOW • SPOKANE, WASHINGTON 99206

SPOKANE PHONE (509) 926-4482

ST. MARIES, IDAHO — PHONE (208) 245-4108

RATHDRUM, IDAHO — PHONE (208) 667-0487

DATE 7/18 1988

PHONE Gary Barton

Box 523

ADDRESS

CITY ST. Marias STATE Id ZIP 83861

WELL DIA. 6" DEPTH 245 YIELD 16.6 +

QNTY.	ITEM	LIST	CHARGE
	Test Pump - new well - Near Emida		
	Static water 115'		
	Pump Set at 240'		
	Running Time 4 hour		
	Pumping Rate from 19 GPM to 16.6		
	Static stabilized at 217' at a		
	pumping Rate of 16.6 GPM		
	Water was clear and free of sand		
	Final yield of well at 16.6 GPM		
	Operator Larry Blair		
	Larry Blair		

RECEIVED
 JAN 30 2009
 IDWR / NORTH

TERMS: NET 10 DAYS FROM INVOICE DATE.
 A finance charge of 1½% (18% corresponding annual
 percentage rate, \$1.00 minimum) will be charged on
 all unpaid balances.

SUB TOTAL	
PUMP TRUCK / LABOR	
SUB TOTAL	
TOTAL DUE	185.00



DEPARTMENT OF ECOLOGY
WATER RESOURCES DIVISION
OLYMPIA, WASHINGTON 98504

AAA PUMP SERVICE, INC.
8. 17 WILLOW
SPOKANE, WA 99206
(509) 928-4462 (206) 245-4108

AQUIFER TEST

Sheet 1 of 1

Tester Gary Barton Location Emda Well No. 1
Date 2/18/88 Meas. by _____ Test _____ County _____
Meas. point Top of 6" casing Elev. Meas. Point _____
Meas. equipment Pump Set at 240'
STW _____ to _____ Q _____ r _____
START STATIC 115

Date	Hour	Water level		TOTAL GALLONS PUMP		$\frac{1440r^2}{t}$	Remarks
		GPM	Depth (DTW)				
	12:40	19.2	115				Water is clear No Sand
	:50		160				
	1:00	17.9	174				
	:10		181				
	:20	17.9	187				
	:30		190				
	:40		194				
	2:00				Shot down		Blown Fusse
	2:15		164				ReStart
	:30		193				
	:40				Shot down		Blown Fusse
	:43						ReStart
	3:00	17.2	203				
	10		207				
	20		212				
	30	17.2	214				
	40		216				
	50		218				
	4:00		220				
	:10	16.9	217			Static	Stable
	:20	16.6	217				"
	4:30	16.6	217				"
	4:40	16.6	217				"

Larry Blair

AAA Pump Service