

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30
days after the completion or abandonment of the well.Department of Water Resources
Northern District Office

1. WELL OWNER

Name Fred J. MooneyAddress Star Route, Coeur d'Alene, IdahoOwner's Permit No. 95-77-N-45

7. WATER LEVEL

Static water level 40 feet below land surfaceFlowing? ☐ Yes ☒ No G.P.M. 1408. Temperature 59 ° F. Quality GoodArtesian closed-in pressure 0.5 p.s.i.Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.

Draw Down

Hours Pumped

15 EST-AIRLIFT

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

(8" to 45' - 6" to 145')

Diameter of hole 8 1/2 inches Total depth 145 feetCasing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>1/2</u> inches	<u>8</u> inches	<u>1</u> feet	<u>45</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☐ Yes ☒ NoWas a packer or seal used? ☒ Yes ☐ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet


Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 18' Material used in seal ☐ Cement groutBentonite ☒ Pudding clay ☐ Well cuttingsSealing procedure used ☐ Slurry pit ☒ Temporary surface casing☐ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County KootenaiSW NE SE Sec. 33 T. 50 N. W R. 4

10.

Work started 5-2-77 finished 5-3-77

11. DRILLERS CERTIFICATION

Firm Name CARMAN DEVELOPMENT Co. Firm No. _____

E. 6010 Broadway, Spokane, Wa. 99206

Address _____ Date 5-23-77Signed by (Firm Official) John Carman

and

(Operator) John Carman