


State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER Name <u>Athony & Jeanne Venturino,</u> Address <u>Hayden Lake, Idaho</u> Owner's Permit No. _____	7. WATER LEVEL Static water level <u>60</u> feet below land surface. Flowing? ☐ Yes ☒ No G.P.M. flow _____ Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature _____ °F. Quality <u>good</u> <i>Describe artesian or temperature zones below.</i>																								
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)	8. WELL TEST DATA ☐ Pump ☐ Bailer ☒ Air ☐ Other _____ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Discharge G.P.M.</th> <th>Pumping Level</th> <th>Hours Pumped</th> </tr> </thead> <tbody> <tr> <td><u>5</u></td> <td></td> <td></td> </tr> </tbody> </table>	Discharge G.P.M.	Pumping Level	Hours Pumped	<u>5</u>																				
Discharge G.P.M.	Pumping Level	Hours Pumped																							
<u>5</u>																									
3. PROPOSED USE ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)	9. LITHOLOGIC LOG <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Bore Diam.</th> <th colspan="2">Depth</th> <th rowspan="2">Material</th> <th rowspan="2">Water Yes No</th> </tr> <tr> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td><u>6</u></td> <td>-</td> <td><u>38</u></td> <td><u>soft decomposed granite</u></td> <td></td> </tr> <tr> <td></td> <td><u>38</u></td> <td><u>84</u></td> <td><u>decomsoed granite</u></td> <td><u>X</u></td> </tr> <tr> <td></td> <td><u>84</u></td> <td><u>104</u></td> <td><u>salt & pepper granite</u></td> <td></td> </tr> </tbody> </table>	Bore Diam.	Depth		Material	Water Yes No	From	To	<u>6</u>	-	<u>38</u>	<u>soft decomposed granite</u>			<u>38</u>	<u>84</u>	<u>decomsoed granite</u>	<u>X</u>		<u>84</u>	<u>104</u>	<u>salt & pepper granite</u>			
Bore Diam.	Depth		Material	Water Yes No																					
	From	To																							
<u>6</u>	-	<u>38</u>	<u>soft decomposed granite</u>																						
	<u>38</u>	<u>84</u>	<u>decomsoed granite</u>	<u>X</u>																					
	<u>84</u>	<u>104</u>	<u>salt & pepper granite</u>																						
4. METHOD DRILLED ☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary ☐ Cable ☐ Dug ☐ Other _____																									
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Thickness</th> <th>Diameter</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td><u>.250</u> inches</td> <td><u>6</u> inches</td> <td>+ <u>1</u> feet</td> <td><u>40</u> feet</td> </tr> <tr> <td></td> <td><u>4" PVC</u> inches</td> <td>-</td> <td><u>100</u> feet</td> </tr> </tbody> </table> Was casing drive shoe used? ☐ Yes ☒ No Was a packer or seal used? ☐ Yes ☒ No Perforated? ☐ Yes ☒ No How perforated? ☐ Factory ☐ Knife ☐ Torch Size of perforation _____ inches by _____ inches <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Number</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>_____ perforations</td> <td>_____ feet</td> <td>_____ feet</td> </tr> <tr> <td>_____ perforations</td> <td>_____ feet</td> <td>_____ feet</td> </tr> <tr> <td>_____ perforations</td> <td>_____ feet</td> <td>_____ feet</td> </tr> </tbody> </table> Well screen installed? ☐ Yes ☒ No Manufacturer's name _____ Type _____ Model No. _____ Diameter _____ Slot size _____ Set from _____ feet to _____ feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>20</u> Material used in seal: ☐ Cement grout ☐ Bentonite ☐ Puddling clay ☐ Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☐ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strata Describe access port _____	Thickness	Diameter	From	To	<u>.250</u> inches	<u>6</u> inches	+ <u>1</u> feet	<u>40</u> feet		<u>4" PVC</u> inches	-	<u>100</u> feet	Number	From	To	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet	_____ perforations	_____ feet	_____ feet	
Thickness	Diameter	From	To																						
<u>.250</u> inches	<u>6</u> inches	+ <u>1</u> feet	<u>40</u> feet																						
	<u>4" PVC</u> inches	-	<u>100</u> feet																						
Number	From	To																							
_____ perforations	_____ feet	_____ feet																							
_____ perforations	_____ feet	_____ feet																							
_____ perforations	_____ feet	_____ feet																							
6. LOCATION OF WELL Sketch map location must agree with written location.  Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Kootenai</u> $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. <u>11</u> T. <u>51</u> N/S, R. <u>3</u> E/W.	10. Work started <u>8-2-84</u> finished <u>8-2-84</u>																								
	11. DRILLERS CERTIFICATION I/we certify that all minimum well construction standards were complied with at the time the rig was removed. <u>Coeur d'Alene Drilling, Inc.</u> 214 Firm Name _____ Firm No. _____ P.O. Box 386 Address <u>Hayden Lake, Idaho</u> Date <u>8-3-84</u> Signed by (Firm Official) <u>Bill E. Fendley</u> and (Operator) <u>Bill E. Fendley</u>																								