

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Administration within 30 days after the completion or abandonment of the well.

NEW OWNER


1. WELL OWNER
Name Len Hodge / Andy Anderson S
Address 1206 Indiana Ave.
Cd'A, Idaho
Owner's Permit No. 95-73-N-42

2. NATURE OF WORK
☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED
☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION
Diameter of hole 6 inches Total depth 105 feet
Casing schedule: ☒ Steel ☐ Concrete
Thickness .250 inches Diameter 6 inches + 1 foot = 87 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches
Number _____ From _____ To _____
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 19' Material used in seal ☐ Cement grout
☒ Puddling clay ☐ Well cuttings
Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing
☒ Overbore to seal depth

LOCATION OF WELL 3571
Sketch map location must agree with written location.

Lakeside addition
Subdivision Name Jenny Lake
Tract _____ Lot No. 46 Block No. _____
County Kootenai
N/E
S.E. % N/E Sec. 23 T. 50 N.R. 3 W.S.M.

7. WATER LEVEL
Static water level 50 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA
☐ Pump ☐ Bailor ☒ Other Air
Discharge G.P.M. Draw Down Hours Pumped
18 ? 2

9. LITHOLOGIC LOG
Hole Diam. Depth From To Material Water Yes No
6" 0 26 Boulders, Brwn/clay X
" 26 40 Brown clay & few boulders X
" 40 60 " " X
" 60 78 Brwn Clay/little gravel X
" 78 80 Broken baselt / Brwn clay X
" 80 105 Black Baselt X

10. Work started Sept 13 -73 finished Sept 15, 1973

11. DRILLERS CERTIFICATION
Firm Name Coeur d'Alene Drilling, inc Firm No. 214
Box 237
Address Hayden Lake, Idaho Date Oct. 19
Signed by (Firm Official) Bill E. Findley
and Paul Kuchick
(Operator)