

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat:	:	Long:	:

1. WELL TAG NO. D0051630

Drilling Permit No:

Other IDWR No.

2. OWNER

Name GASKIN, DAVID

Well Number:


1278

Address 505 W. MULBERRY

City PORTERVILLE State CA Zip 93257

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 53N ☒ North or ☐ SouthRge. 03W ☐ East or ☒ West

Sec. 11 N 1/4 NE 1/4 NE 1/4

Gov't Lot County KOOTENAI

Lat: N47: 57 : 66 Long: W116 39 : 48

Address of Well Site 10240 E. Howard Rd.

City ATHOL

(Give at least name of road + Distance to Road or Landmark)

Lt. 3 Blk. Sub. Name CRESTWOOD

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	650 LBS	DRY POUR

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) R.BWas drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	440	.250	STEEL	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations Method☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

350 ft. below ground Artesian pressure lb.

Depth flow encountered 360 ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15 - 20 GPM	100	440	2.5 HRS

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: CLEAR

Depth first Water encountered 360

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	18	Top Soil & Gravels	☐	☒
8	18	79	Sand & Gravel	☐	☒
8	79	114	Tan Clay w/ Gravels	☐	☒
8	114	285	Sand & Gravel	☐	☒
8	285	319	Sand & Gravel w/ Clay	☐	☒
8	319	381	Sand & Gravel	☒	☐
8	381	386	Boulder	☐	☒
8	386	445	Gravels with Sand	☐	☒

Completed Depth 440 (Measurable)
Date: Started 2/21/2007 Completed 2/26/2007

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date

and

Supervisor or Operator Date 2/28/07

J.R. CANTRELL

(Sign Once If Firm Official and Operator)