

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4 _____	1/4 _____	1/4 _____
Lat: _____	Long: _____	

1. WELL TAG NO. D0013762

DRILLING PERMIT No _____

Other IDWR No _____

2. OWNER:

Name **Marty Hernandez**

Address P O Box 1477

City Hayden

State ID _____

Zip 83835

3. LOCATION OF WELL by legal description:

N				Twp	53N	North	☒ or	South		
				Rge	03W	East	☐ or	West	☒	
				Sec	36	1/4	SE	1/4	NE	1/4
						10 Ac	40 Ac	160 Ac		
				Gov't Lot			County	Kootenai		
				Lat			Long			

Address of Well Site: (see next line)

1 mile N on Nunn to Infinity Road, r first drive on r

City _____

Lot _____

Blk _____

Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	19	5 sacks	dry pour

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) _____

19

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	1	19	0.250	Steel	☒		☒	
4	10	300	0.165	PVC		☒		

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____☒ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
260	300	.040			PVC		☒

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

18 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered _____ 50 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

Pump ☐ Bailer ☐☒ Air☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
10	100%	295	1 hr.

Water Temp. _____ cold

Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 35

clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	7	Topsoil/gravel		☒
8	7	12	Granite - decomposed		☒
8	12	19	Granite - black/white - firm		☒
6	19	35	Granite - black/white - firm		☒
6	35	37	Granite - decomposed	☒	
6	37	50	Granite - black/white firm		☒
6	50	56	Granite - broken		☒
6	56	75	Granite - decomposed		☒
6	75	174	Granite - black/white		☒
6	174	180	Granite - decomposed		☒
6	180	292	Granite - black/white		☒
6	292	300	Granite - green - soft		☒

PUMP INFO

HP 1 1/2

RPM 3450

Completed Depth 300 (Measurable)

Date: Started 9/14/00 Completed 9/15/00

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Name _____

Firm No 414

Firm Official _____
and _____

Date 9/15/00

Supervisor or Operator Curtis S. Hammond

Date 9/15/00

WELL TEST

Customer: Marty Hernandez **Address:** PO Box 1477
Hayden ID 83835

Job Location: 1 Mile N on Nunn to Infinity **Phone No:** 208-667-2400

WELL DATA COPY

Total Depth: 299' **Test Pump Used:** 1 1/2 HP, 10 GPM
Static Water Level: 20' **Pump Setting:** 293.5
Driller Tested: 10 GPM **Date of Test:** 12/04/00

Time	Flow Rate Gallons Per Minute	Pressure Per Square Inch	Water Quality	Static Level
11:00 AM	4.00	200+	Dark Brown/fine sand	20'
11:15 AM	4.00	200+	Dark Brown/fine sand	Unknown
11:30 AM	4.00	200+	Dark Brown/fine sand	Unknown
11:45 AM	4.00	200+	Light Brown/fine sand	Unknown
12:00 PM	11.54	120.00	Light Brown/no sand	Unknown
12:15 PM	15.79	0.00	Light Brown/no sand	Unknown
12:30 PM	15.79	0.00	Light Brown/no sand	Unknown
12:45 PM	15.79	0.00	Light color	Unknown
1:00 PM	15.79	0.00	Light color	Unknown
1:15 PM	15.79	0.00	Light color	Unknown
1:30 PM	15.79	0.00	Light color	Unknown
1:45 PM	15.79	0.00	Color/no sediment	Unknown
2:00 PM	15.79	0.00	color	Unknown
2:15 PM	15.79	0.00	color	Unknown
2:30 PM	15.79	0.00	color	Unknown
2:45 PM	15.79	0.00	color	Unknown
3:00 PM	15.79	0.00	color	Unknown

TEST SUMMARY: 12.77 was the average gallons per minute produced by this well over the four-hour test period.

Certified by:



Richard A. Agueros, President
UNITED PUMP COMPANY

88994

1217431

1183883 WARRANTY DEED

COPY

For Value Received RALPH D. KIZER and DORIS D. KIZER, husband and wife

The grantor, do hereby grant, bargain, sell and convey unto MARTIN HERNANDEZ and DOLORES HERNANDEZ, husband and wife

the grantee, whose current address is ~~12623 E. Imperial Hwy. #205~~
~~Santa Fe Springs, CA 90670~~1021 Concourse St.
La Habra, CA 90631

the following described premises, in Kootenai

County Idaho, to-wit:

SEE ATTACHED

STATE OF IDAHO }
COUNTY OF KOOTENAI } SS
AT THE REQUEST OF
SECURITY TITLE COMPANY

* MAY 10 4 26 PM '91


D. B. Leonard
FEE \$ 6.00 DEPUTY

TO HAVE AND TO HOLD the said premises, with their appurtenances unto the said Grantee heirs and assigns forever. And the said Grantor do hereby covenant to and with the said Grantee, that he the owner in fee simple of said premises; that they are free from all incumbrances EXCEPT: current year taxes, conditions, covenants, restrictions, reservations, easements, rights and rights of way, apparent or of record

and that he will warrant and defend the same from all lawful claims whatsoever.

Dated: May 25, 1990


 Ralph D. Kizer


 Doris D. Kizer

STATE OF IDAHO, COUNTY OF Kootenai
 On this 25th day of May, 1990
 before me, a notary public in and for the said State, personally

STATE OF IDAHO }
 COUNTY OF KOOTENAI } SS
 AT THE REQUEST OF
 SECURITY TITLE COMPANY

INSTRUM