

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
_____ 1/4	_____ 1/4	_____ 1/4	
Lat: _____		Long: _____	

1. WELL TAG NO. **D0022266**

DRILLING PERMIT N _____

Other IDWR No _____

2. OWNER:

Name **Lynn Darwood**Address **P O Box 5**City **Spirit Lake**State **Id**Zip **83869**

3. LOCATION OF WELL by legal description:

N			
		X	
S			

Twp **50N** North ☒ or South ☐
Rge **05W** East ☐ or West ☒
Sec **26** 1/4 NW 1/4 NE 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County **Kootenai**
Lat _____ Long _____

Address of Well Site: (see next line)

51 W Deer Meadows Lane, stay right to end

City _____

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	5 sacks	pour in

ive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____ive Shoe Seal Tested? ☐ Y ☒ N How? _____

CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	1	159	0.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

PERFORATIONS/SCREENS

Perforations? _____ Method **air perforator**

Screens? _____ Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
20	140	1X1/4			Steel	☒	☐
						☐	☐
						☐	☐

STATIC WATER LEVEL or ARTESIAN PRESSURE

5 ft. below ground. Artesian pressure _____ lb.

h flow encountered _____ 105 ft. Describe access port or

ol devices: **Steel cap welded**

11. WELL TESTS:

Pump _____

Bailer _____

☒ Air

Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20+	100%	150	1 hr.

Water Temp. _____ cold

Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered **105**
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
8	0	18	Brown, sand with gravel	Y	N
6	18	50	Brown sand with gravel	☒	☐
6	50	70	Sand & gravel - 3/4 minus	☒	☐
6	70	85	Sand & gravel - 1/4" minus	☒	☐
6	85	136	Sand & gravel - 3/4 minus	☒	☐
6	136	159	Sand & gravel - 1/2" minus	☒	☐

PRECISE
CUT 1 HP

HOUSE

W 50'

TEMP
POWER
600' away
GO W/ #8 DOWNHOLE

Completed Depth

150

(Measurable)

Date: Started

4/30/02

Completed

4/30/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name **United Drilling Inc.**Firm No **414**Firm Official
and**Jason C. Beckham**Date **5/1/02**Supervisor or Operator **Jason C. Beckham**Date **5/1/02**

FORWARD WHITE COPY TO WATER RESOURCES