

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat		Long	

1. WELL TAG NO. D0041356

Drilling Permit No: 838965

Other IDWR No.

2. OWNER

Name MARENO, ANTHONY

Well Number:

1139


Address P.O. BOX 629

City ATHOL

State ID Zip 83801

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 53N ☒ North or ☐ South

Rge. 03W ☐ East or ☒ West

Sec. 05 1/4 SW 1/4 SE 1/4

Gov't Lot County KOOTENAI

Lat. : Long. :

Address of Well Site 134334 Sheep Springs Rd
City Athol

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	20	600 lbs	Overbore

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) R.B.

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	522	.250	Steel	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

Perforations		Method					
Screens		Screen Type					
From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

460 ft. below ground Artesian pressure lb.
Depth flow encounter 520 ft. Describe access port or control devices:

53N 3W 5

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
20			1 hr

Water Temp. Cold Bottom Hole Temp. Cold

Water Quality test or comments: Cloudy

Depth first Water encountered 460

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	Y	N
10	0	18	Soil w/ Gravels			
8	18	350	Sand & Gravels			
8	350	378	Cemented Gravels w/ Clay			
8	378	524	Sand & Gravels w/ Clay Seams			

RECEIVED

MAY 02 2006

IDWR/North

Completed Depth 522 (Measurable)
Date: Started 4/17/2006 Completed 4/20/2006

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448
Firm Official [Signature] Date 4-26-06

Supervisor or Operator [Signature] Date 4/21/06
Louie Hanner (Sign Once if Firm Official and Operator)