

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCESUSE TYPEWRITER OR
BALLPOINT PEN

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Edward P. O'Hara
Address W. 5445 Nelson Loop Road
Rathdrum, ID 83858Owner's Permit No. 95-84-N-93

2. NATURE OF WORK

- ☒
- New well
- ☐
- Deepened
- ☐
- Replacement
-
- ☐
- Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE

- ☒
- Domestic
- ☐
- Irrigation
- ☐
- Test
- ☐
- Municipal
-
- ☐
- Industrial
- ☐
- Stock
- ☐
- Waste Disposal or Injection
-
- ☐
- Other _____ (specify type)

4. METHOD DRILLED

- ☒
- Rotary
- ☒
- Air
- ☐
- Hydraulic
- ☐
- Reverse rotary
-
- ☐
- Cable
- ☐
- Dug
- ☐
- Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>19</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____


Placed from _____ feet to _____ feet

Surface seal depth 19 Material used in seal: ☐ Cement grout☒ Bentonite ☐ Puddling clay ☐ _____Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing☒ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent☐ Weld☐ Cemented between strata

Describe access port _____

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County KOOTENAINE-NE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 17 T. 52N N/S R 3W E/M

7. WATER LEVEL

Static water level 20 feet below land surface.Flowing? ☐ Yes ☒ No G.P.M. flow _____

Artesian closed-in pressure _____ p.s.i.

Controlled by: ☐ Valve ☐ Cap ☐ Plug

Temperature _____ of. Quality _____

Describe artesian or temperature zones below.

8. WELL TEST DATA

☐ Pump ☐ Bailor ☒ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>2 GPM - ESTIMATED AIRLIFT</u>		

9. LITHOLOGIC LOG

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
10"	0	9	Clay & sand mixed		
10"	9	11	Shale, clay		X
10"	11	19	Shale, gray & green		X
6"	19	75	Shale, gray & green		X
6"	75	80	Shale, fractured w/water		X
6"	80	200	Shale, gray, green & white	X	
6"	200	215	Shale, green & white w/water		X
6"	215	360	Shale, gray, green & white w/fractures	X	

360' PVC Liner Installed

6" Drive shoe installed

RECEIVED
JAN 7 1985

DEC 16 1984

Department of Water Resources
Northern District Office

10.

Work started 11/29/84 finished 11/30/84

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name PONDEROSA DRILLING Firm No. 228Address E. 6010 Broadway
Spokane, WA 99212 Date 11/30/84Signed by (Firm Official) W. Scott Barlett
and W. Scott Barlett
(Operator) W. Scott Barlett