

RECEIVED

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

097895

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long

NORTHERN REGION

1. DRILLING PERMIT NO. 95-97-N-035-000

Other IDWR No.

2. OWNER

Name ELLINGSON, BRUCE

Well Number:

595


Address 1930 SE BLVD

City SPOKANE

State WA Zip 99203

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 51 ☒ North or ☐ South

Rge. 03 ☐ East or ☒ West

Sec. 21 1/4 NW 1/4 NE 1/4

Gov't Lot County KOOTENAI

Lat: : Long: :

Address of Well Site WINDY BAY

City HAYDEN LAKE

(Give at least name of road + Distance to Road or Landmark)

Bk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	38	6 SACKS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 38

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2	38	.250	STEEL	☒	☐	☒
4	-8	203	.160	PVC	☐	☒	☐

Length of Headpipe

Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
163	203	1/8X4	140	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

42 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump	☐ Bailer	☒ Air	☐ Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
16 GPM			1 HR

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	35	Granite Decomposed Brown	☐	☒
6	35	53	Granite Brown Medium	☐	☒
6	53	87	Granite Salt & Pepper	☒	☐
6	87	114	Granite White Green & Rose W/Water	☒	☐
6	114	143	Granite Salt & Pepper	☒	☐
6	143	152	Granite White Green & Rose 10-12 gp	☒	☐
6	152	203	Granite Salt & Pepper	☐	☒

Completed Depth 203' (Measurable)

Date: Started 8/19/97 Completed 8/19/97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Date 9-11-97

and Supervisor or Operator Date 9-9-97

(Sign Once if Firm Official and Operator)

NWNE 21 51N 3W