

RECEIVED

Form 11/97
SEP 01 1999

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 076557

IDWR/North

1. WELL TAG NO. 10332
DRILLING PERMIT NO. 44-99-N-37
Other IDWR No. _____

2. OWNER:
Name Neil Garner
Address E 29125 Schlagel Drive
City Cataldo State ID Zip 83810

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

North ☒ or South ☐
East ☒ or West ☐
Twp. 49 Rge. 1 Sec. 19
Gov't Lot _____ County Boone Lat. _____ Long. _____
Address of Well Site E 29125 Schlagel City Cataldo

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Feet	Pounds	
<u>Bentonite</u>	<u>0</u>	<u>98</u>	<u>500#</u>		<u>Pow Dry</u>

Was drive shoe used? ☒ N Shoe Depth(s) 133
Was drive shoe seal tested? ☒ N How? Hi

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>+2</u>	<u>133</u>	<u>.250</u>	<u>Steel</u>	☒	☐	☒	☐

Length of Headpipe N/A Length of Tailpipe N/A

9. PERFORATIONS/SCREENS

Perforations Method N/A
Screens Screen Type N/A

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

21 ft. below ground Artesian pressure N/A lb.
Depth flow encountered 125 ft. Describe access port or control devices: Well Cap

49N 1E 19

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Lat. _____ Long. _____

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>10</u>			<u>1 hr</u>

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: Clear

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0</u>	<u>15</u>	<u>Gravel</u>	☒	
<u>8"</u>	<u>15</u>	<u>28</u>	<u>Clay Grey</u>		☒
<u>8"</u>	<u>28</u>	<u>94</u>	<u>Clay brown</u>		☒
<u>8"</u>	<u>94</u>	<u>98</u>	<u>Clay Grey</u>		☒
<u>6"</u>	<u>98</u>	<u>124</u>	<u>Clay Grey</u>		☒
<u>6"</u>	<u>124</u>	<u>150</u>	<u>Granite broken green</u>	☒	

Completed Depth 150' (Measurable)
Date: Started 8-19-99 Completed 8-19-99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-ways Drilling Inc. Firm No. 510
Firm Official Paul K. [Signature] Date 8-20-99
and Driller or Operator Will [Signature] Date 8-20-99
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES