

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTUSE TYPEWRITER OR
BALLPOINT PENState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Mike Pratt
Address RATHRUM, IDAHO
Owner's Permit No. 96-77-N-187

7. WATER LEVEL

Static water level 47 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow 8
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature _____ °F. Quality _____

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Air ☐ Other _____

Discharge G.P.M. _____ Pumping Level _____ Hours Pumped _____

Air Test
Approx. 16 GPM

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____Thickness _____ inches Diameter _____ inches + _____ feet To _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feetWas casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inchesNumber _____ From _____ feet To _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feetWell screen installed? ☐ Yes ☒ No
Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 19' Material used in seal: ☐ Cement groutBENTONITE ☒ Pudding clay ☐ Well cuttingsSealing procedure used: ☐ Slurry pit ☐ Temp. surface casing☐ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata

Describe access port _____

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water Yes No
	From	To		
6"	0	1	Top Soil	
	1	42	DECOMPOSED GRANITE	
	42	300	HARD GRANITE	

We would address
water at all times
while drilling so it
hard to be sure where
this total of 1 GPM
was encountered, but
it was before the
300' mark.

RECEIVED

JUN 11 1979

Department of Water Resources
Northern District Office

RECEIVED

APR 30 1979


Department of Water Resources
Northern District Office (3939)

10.

Work started 7/9/77 finished 7/10/77

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County KOOTENAINE 1/4 NE 1/4 Sec. 30, T. 53N N/S, R. 3E (W)

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
compiled with at the time the rig was removed.Firm Name J & J Drilling Co. Firm No. 319Address 5613 S. Lincoln Rd. Date 4/24/79Signed by (Firm Official) Gerald A. Johnsonand
(Operator) Same