

RECEIVED
Form 238-7
11/97
DEC 23 1998

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
Lat: : : Long: : :
77883

IDWR/North

1. WELL TAG NO. D0005714

DRILLING PERMIT NO. 95-98-N-225

Other IDWR No. _____

2. OWNER:

Name Lee & Sky Hagen

Address 4445 E Holmes RD

City Rathdrum

State ID

Zip 83858

3. LOCATION OF WELL by legal description:

N Twp 52N North ☒ or South ☐
Rge 04W East ☐ or West ☒
Sec 21 1/4 NE 1/4 SE 1/4
Gov't Lot 10 Ac 40 Ac 160 Ac
County Kootenai
Lat _____ Long _____

Address of Well Site: (see next line)

53 to Atlas end of payment go left take first left and City

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	-18	13 sacks	pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	1	-335	0.025	steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____

Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

255 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 255 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
40+	100%	25	2 Hrs.

Water Temp. cold

Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 255
clear, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	1	Topsoil	☐	☒
8	1	18	Sand & gravel - 3/4 minus	☐	☒
6	18	160	Sand & gravel - 3/4 minus	☐	☒
6	160	206	Sand & gravel - fine - 3/8 minus	☐	☒
6	206	260	Fine sand	☒	☐
6	260	316	Clay, silt & sand - gray	☒	☐
6	316	335	Sand & gravel - 3/4 minus	☒	☐

Completed Depth 330 (Measurable)
Date: Started 12/16/98 Completed 12/18/98

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 414

Firm Official and

Jason C. Beckham

Date 12/21/98

Supervisor or Operator Jason C. Beckham

Date 12/21/98

FORWARD WHITE COPY TO WATER RESOURCES

52N 4W 21