

RECEIVED

IDAHO DEPARTMENT OF WATER RESOURCES

NOV 13 1996

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

007252

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	:	Long:

1. DRILLING PERMIT NO. 96-96-N-802-000

Other IDWR No.

2. OWNER

Well Number:

Name RUND, TONY


501

Address 1704 S MAPLE BLVD

City SPOKANE State WA Zip 99203

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 53



North or



South

Rge. 05



East or



West

Sec. 14

1/4 SE

1/4 NE

1/4

Gov't Lot

County

KOOTENAI

Lat:

Long:

Address of Well Site

City

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	2 BAGS	OVERBORE

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) 0Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	18	.250	STEEL	☒	☐	☒	☐
4	-8	163	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
123	163	1/8X4	140	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

85 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5 GPM			

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	8	Granite Decomposed Soft	☐	☒
8	8	18	Granite Tan Medium	☐	☒
6	18	24	Granite Tan Medium	☐	☒
6	24	53	Granite Black & Copper Medium Soft	☐	☒
6	53	113	Granite White Black Copper Medium	☐	☒
6	113	125	Granite Black Copper Brown Soft W/	☒	☐
6	125	135	Granite White Black Medium	☐	☒
6	135	141	Granite Black Copper Brown W/Water	☒	☐
6	141	163	Granite Black Copper White Medium	☐	☒

Completed Depth 163' (Measurable)

Date: Started 10/31/96 Completed 10/31/96

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name N20 Well Service Inc. Firm No. 448

Firm Official Date 11-7-96

and Supervisor or Operator Date 11-7-96

(Sign Once as Firm Official and Operator)

SENE 14 53N 5W