

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat: : : Long: : :

1. WELL TAG NO. D0017041

RECEIVED

11. WELL TESTS:

DRILLING PERMIT N

Other IDWR No

767943

MAR 19 2001

2. OWNER:

Name Kevin Ekness

IDWR North

Address 2590 Meyer rd

City Post Falls

State ID

Zip 83854

3. LOCATION OF WELL by legal description:

N
W E S
Twp 51N North ☒ or South ☐
Rge 04W East ☐ or West ☒
Sec 29 1/4 SW 1/4 SW 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Kootenai
Lat _____ Long _____
Address of Well Site: (see next line)

2590 Meyer Road

City

Lot

Blk

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	12 sacks	pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s)

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	258	0.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe

Length Tailpipe

9. PERFORATIONS/SCREENS

- ☒ Perforations? Method air perforator
☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
238	258	1"	400		Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

210 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 210 ft. Describe access port or

control devices: Steel cap welded

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20+	100%	258	1 hr.

Water Temp. _____ cold Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 210
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water
8	1	3	Topsoil	☒
8	3	8	Sand & gravel - 3/4 Minus	☒
8	8	14	Boulder	☒
8	14	19	Sand & gravel - 3/4" minus	☒
6	19	80	Sand & gravel - 3/4" minus	☒
6	80	210	Sand & gravel - 1/4" minus	☒
6	210	258	Sand & gravel - 3/4" minus	☒

Completed Depth 258 (Measurable)
Date: Started 2/5/01 Completed 2/6/01

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Firm No 414

Firm Official
and

Timothy R. Volking

Date 2/8/01

Supervisor or Operator Timothy R. Volking

Date 2/8/01

FORWARD WHITE COPY TO WATER RESOURCES