

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____		1/4 _____	
Lat: _____	Long: _____	_____	

1. WELL TAG NO. D0040618Drilling Permit No: 835851

Other IDWR No. _____

2. OWNER

Name PERRINE, GERALDWell Number: 1038Address 8313 BROOKSIDE DRIVECity HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N			
Twp. 52 ☒ North or ☐ South			
Rge. 04 ☐ East or ☒ West			
Sec. 23 <u>1/4 SW 1/4 SW 1/4</u>			
Gov't Lot _____ County <u>KOOTENAI</u>			
Lat: _____ Long: _____			

Address of Well Site LONE PINE OFF
OHIO MATCH City HAYDEN

(Give at least name of road + Distance to Road or Landmark)

Lt. 5 Blk. 1 Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	500 LBS	MP SUFACE CAS

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 338Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	338	.250	STEEL	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Linor

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

280 ft. below ground Artesian pressure _____ lb.

Depth flow encountere _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
50+			

Water Temp. COLD Bottom Hole Temp COLDWater Quality test or comments: CLEARDepth first Water encountered 280

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	3	TOP SOIL	☐	☒
8	3	200	SANDS, GRAVELS, 3/4 MINUS	☐	☒
8	200	245	CEMENTED SANDS, GRAVELS	☐	☒
8	245	280	SANDS, GRAVELS, 3/4 MINUS	☐	☒
8	280	338	SANDS, GRAVELS, 3/4 MINUS 50GP	☒	☐
8	338	340	CLAY, WHITE, HARD PAN	☐	☒

Completed Depth 340 (Measurable)Date: Started 9/9/2005 Completed 9/13/2005

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448Firm Official Thomas R. Halterma Date 9-19-05

and

Supervisor or Operator Michael Halterma Date 09/14/05

MIKE HALTERMA (Sign Once if Firm Official and Operator)

52N 4W 23