

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCESUSE TYPEWRITER OR
BALLPOINT PEN

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

ENT'D

1. WELL OWNER

Name HARRY M. WIKSAddress MARINE STOwner's Permit No. COEUR D'ALENE 085874
95-81-N-30

7. WATER LEVEL

Static water level 0 feet below land surface.Flowing? ☒ Yes ☐ No G.P.M. flow 12Artesian closed-in pressure 0 p.s.i.Controlled by: ☐ Valve ☒ Cap ☐ PlugTemperature °F. Quality GOOD

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☐ Baller ☐ Air ☐ Other

Discharge G.P.M.

Pumping Level

Hours Pumped

8 gpm

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal☐ Industrial ☐ Stock ☐ Waste Disposal or Injection☐ Other (specify type)

4. METHOD DRILLED

☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary☐ Cable ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other

Thickness	Diameter	From	To
<u>0.25</u> inches	<u>6</u> inches	<u>1</u> feet	<u>29</u> feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet


Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☒ Yes ☐ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ TorchSize of perforation inches by inches

Number	From	To
perforations	feet	feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☒ NoManufacturer's name Type Model No. Diameter Slot size Set from feet to feetDiameter Slot size Set from feet to feetGravel packed? ☐ Yes ☒ No Size of gravel Placed from feet to feetSurface seal depth 29 Material used in seal: ☐ Cement grout☒ Puddling clay ☐ Well cuttingsSealing procedure used: ☐ Slurry pit ☒ Temp. surface casing☐ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent☐ Cemented between strataDescribe access port

9. LOCATION OF WELL

Sketch map location must agree with written location.

Subdivision Name Lot No. Block No. County FOOTENAISW 1/4 SW 1/4 Sec 26, T. 49 N/S, R. 4 W.

10.

Work started 5-11-81 finished 5-12-81

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
complied with at the time the rig was removed.Firm Name NORTWEST WATER Firm No. 385Address 1000 E. 10th St. Date 5-12-81Signed by (Firm Official) [Signature]

and

(Operator) Duncan S. Lickford