USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Water Resources

WELL DRILLER'S REPORT

RECEIVED
AUG 18 1976
Department of Water Resources
Northern District Office

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name JERRY NEWIN

Address 3201 MARYLAND PL. BELLINGHAM, WASH

Owner's Permit No.

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 226 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
.250 inches	6 inches +	1 feet	101 feet
inches	inches	feet	feet
inches	inches	feet	feet
PVC inches	4 inches	5.60 feet	226 feet
inches	inches	feet	feet

Was casing drive shoe used? ☐ Yes ☐ No

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☒ Yes ☐ No

How perforated? ☐ Factory ☐ Knife ☒ Torch

Size of perforation 5 inches by 216 inches

Number	From	To
10 perforations	216 feet	227 feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name

Type Model No.

Diameter Slot size Set from feet to feet

Diameter Slot size Set from feet to feet

Gravel packed? ☐ Yes ☒ No Size of gravel

Placed from feet to feet

Surface seal depth 20 Material used in seal ☐ Cement grout ☒ Puddling clay ☒ Well cuttings

Sealing procedure used ☐ Slurry pit ☒ Temporary surface casing ☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name

Lot No. Block No.

County KOOTENAI

SE ¼ SW ¼ Sec. 15, T. 51 N/S, R. 3 E/W

7. WATER LEVEL

Static water level 35 feet below land surface

Flowing? ☐ Yes ☒ No G.P.M. flow

Temperature ° F. Quality

Artesian closed-in pressure p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6	0	1	RED CLAY		X
	1	63	DECOMPOSED GRANITE		X
	63	102	MED. GRANITE	X	
	102	118	SOFT GRANITE		
	118	226	MED. GRANITE		

10.

Work started 7/2/76 finished 7/5/76

11. DRILLERS CERTIFICATION

Firm Name HOME DRILLING & DEV. INC Firm No. 163

Address P.O. BOX 1199 C PA Date 7/6/76

Signed by (Firm Official) Richard Brian Brandt

and

(Operator) [illegible]

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE COPY TO DEPARTMENT