Form 238-7
3/95

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

RECEIVED
FEB 14 1996
IDWR

Office Use Only
Inspected by _____
Twp____ Rge____ Sec____
____1/4 ____1/4 ____1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. 95-95-N-124-000
Other ID WR

2. OWNER:
Name Michael and Susan Browning
Address E 6050 Doncello RD
City Rathdrum State ID Zip 83858

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 52 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 10, ____ 1/4 NE 1/4 SE 1/4
Gov't Lot ____ County Kootenai
Lat: : : Long: : :
Address of Well Site E 6050 Doncello RD
(Give at least name of road + Distance to Road or Landmark) City Rathdrum

Lt.____ Blk.____ Sub. Name____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other____

6. DRILL METHOD
☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	30	100	Surface Casing

Was drive shoe used? ☒Y ☐N Shoe Depth(s)____
Was drive shoe seal tested? ☐Y ☐N How?____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	0	340	250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe____ Length of Tailpipe____

9. PERFORATIONS/SCREENS
☐ Perforations Method____
☐ Screens Screen Type____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
287 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:____

NESE 10 52N 4W

11. WELL TESTS:
☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
40 GPM	0		

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments: ____
Depth first Water Encountered ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
10	0	5	Brown top soil		X
10	5	30	Clay and Gravel		X
8	30	45	Clay and Boulders		X
8	45	210	Clay and Gravel		X
8	210	287	Boulds and Cemented Gravel		X
8	287	340	Sand and Gravel	X	

MICROFILMED
JAN 09 1998

Completed Depth 340 (Measurable)
Date: Started July 1 95 Completed July 15 95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name McQuade Drilling DBA Blue Water Drilling Firm No. 452
Firm Official John Carmon Date Aug 1 1995
and
Supervisor or Operator____ Date____
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES