Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
APR 14 1999
IDWR/North

076838

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

1. WELL TAG NO. D 0005477
DRILLING PERMIT NO. 98-99-N-17-100
Other IDWR No. 96-99-N-17-102

2. OWNER:
Name Richard Caldwell
Address 24385 McCoy Rd
City Athol State ID Zip 83801

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 53 North ☒ or South ☐
Rge. 2 East ☐ or West ☒
Sec. 35 , ____ 1/4 SW 1/4 NE 1/4 (10 acres / 40 acres / 160 acres)
Gov't Lot ____ County Kootenai
Lat: : : Long: : :
Address of Well Site same
City _____
(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

POSTED

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☐ New Well ☒ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD

Was drive shoe used? ☐Y ☐ N Shoe Depth(s) _____
Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
4	-30	450	160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
Perforations Method saw
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
430	450	163/8			pvc	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
130 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices: cap

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
7		450	2hrs

Water Temp. cold Bottom hole temp. ____
Water Quality test or comments: _____
Depth first Water Encounter 40

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Wate Y
6	205	390	salt/pepper	
	390	400	broken salt/pepper	X
	400	450	salt/pepper	X

Completed Depth 450ft (Measurable)
Date: Started 1/26 Completed 1/29/99

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Bronson Water Wells Firm No. 360
Firm Official R D Bronson Date 1/29/99
and
Driller or Operator _____ Date _____
(Sign once if Firm Official & Operator)

53N 2W 35

FORWARD WHITE COPY TO WATER RESOURCES