

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4	1/4	1/4
Lat: _____	Long: _____	

1. WELL TAG NO. **D0035413**

DRILLING PERMIT N

824025**RECEIVED**

11. WELL TESTS

Other IDWR No

SEP 28 2004

Pum

Bailer

☒ Air

Flowing Artesian

2. OWNER:

Name **Vince Peak****IDWR/North**Address **PO Box 614**City **Athol**State **ID**Zip **83801**

3. LOCATION OF WELL by legal description:

N		Twp	53N	North	☒ or	South
W		Rge	03W	East	☐ or	West ☒
E		Sec	03	1/4	NW	1/4 NW 1/4
S		10 Ac 40 Ac 160 Ac				
		Gov't Lot	County Kootenai			
		Lat	Long			

Address of Well Site: (see next line)

Forestdale to Roberts Road

City **Athol**

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Grans	0	18	18 sacks	Pour In

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) **423** Ring BitDrive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	423	0.250	Steel	☒	☐	☒	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method **Air Perforator**
☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
400	420	1x1/4	200	6	Steel	☒	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

360 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered **360** ft. Describe access port orcontrol devices: **Steel Cap Welded**

Yield gal./min.	Drawdown	Pump Level	Time
20+	100%	419	1 Hour

Water Temp. _____ Cold Bottom hole temp. _____ Cold

Water Quality test or comments: (below) Depth first Water Encountered **360**

Cold, Clear and No Smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	1	Topsoil	☐	☒
8	1	80	Sand and Gravel 3/4 Minus	☐	☒
8	80	120	Sand and Gravel 1/8 Minus	☐	☒
8	120	280	Sand and Gravel 3/4 Minus	☐	☒
8	280	340	Sand and Gravel 1/2 Minus	☐	☒
8	340	423	Sand and Gravel 3/4 Minus	☒	☐

Completed Dept **423** (Measurable)
Date: Started **9/1/2004** Complete **9/2/2004**

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name	United Drilling Inc.	Firm N	414
Firm Official and	<i>Jason C. Beckham</i>	Date	9/7/2004
Supervisor or Operator	Jason C. Beckham	Date	9/7/2004

53N 3W 3