Form 238-7
7/98
Starships Consulting and Management Services

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by_____
Twp____Rge____ Sec____
____1/4____1/4____1/4
Lat: : : Long: : :

1. WELL TAG NO. D0028493
Drilling Permit No: _____
Other IDWR No. _____

2. OWNER **Well Number:** 584
Name DAVIS, STUART & NANCY
Address 427 E. DANA RD.
City HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description
sketch map location must agree with written location

N / W / E / S — X

Twp. 53 ☑ North or ☐ South
Rge. 3 ☐ East or ☑ West
Sec. 25 ____ 1/4 SE 1/4 SW 1/4
Gov't Lot ____ County KOOTENAI
Lat: : : Long: : :
Address of Well Site NUNN RD.
City ATHOL
(Give at least name of road + Distance to Road or Landmark)
Lt.____ Blk. ____ Sub. Name ____

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK check all that apply (Replacement, etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other ____

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
DRY GRANULE				
BENTONITE	0	18	10 BAGS	OVERBORE

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) 112
Was drive shoe seal tested? ☐ Y ☑ N How? ____

8. CASING/LINER:

Diameter	From	To	Gauge	Materi	Casing	Liner	Welded	Threaded
6	+3	112	.250	STEEL	☑	☐	☑	☐

Length of Headpipe 5' Length of Tailpipe)

9. PERFORATIONS/SCREENS
☐ Perforations Method ____
☑ Screens Screen Type STAINLESS STEEL

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
113	118	12	1	6	SS	☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
85 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 85 ft. Describe access port or control devices: ____

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10+		118'	2 HRS

Water Temp. COLD Bottom Hole Temp COLD
Water Quality test or comments: CLEAR
Depth first Water encountered 85

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
10	0	3	Top Soil	☐	☐
10	3	18	Sand & Gravel w/ Clay Seems	☐	☐
8	18	120	Sand & Gravel w/ Clay Seems 85' Wa	☑	☐

COPY

Completed Depth 118 (Measurable)
Date: Started 6/13/03 Completed 6/13/03

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name **H20 WellService, Inc.** Firm No. **448**
Firm Official ____ Date ____
and
Supervisor or Operator ____ Date ____
(Sign Once if Firm Offical and Operator)

(Louie Hanner)