

Use Typewriter or Ballpoint Pen

11. WELL TESTS:

☐ Pump ☐ Bailer

City POST FALLS State ID Zip 83854

Sketch map location must agree with written location.

Address of Well Site **NUNN RD**

(Give at least name of road - Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) _____
Was drive shoe seal tested? ☐ Y ☒ N How? _____

Length of Headpipe _____ Length of Tailpipe _____

☐ Perforations Method _____

☐ Screens Screen Type _____

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
70 ft. below ground Artesian pressure lb.
Depth flow encountered 82 ft. Describe access port or control devices: Steel cap welded

70 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 82 ft. Describe access port or control devices: Steel cap welded

Water Temp. cold Bottom hole temp. cold
Water Quality test or comments: clear, cold & no smell

3F HOWE L843
GARDEN
WOOD LAWN.

244

44

$$u = 100$$

1 HP 10

2 HP 10

Completed Depth 137' (Measurable)
Date: Started 3/02/07 Completed 3/03/07

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No. 414

Firm Official Timothy J. Walling, Jr. Date 3/17/07

Supervisor or Operator Jason C. Beckham Date 3/17/97

(Sign once if Firm Official & Operator)