RECEIVED
JUN 26 1995
IDWR

POSTED

R N9108 #356 6/26/95

Form 238-7
7/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. ~~96~~ 95-N-137-
Other IDWR No.

2. OWNER:
Name Bob Van Zile Realty
Address W601 Riverside
City Spokane State WA Zip 99201

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.



Twp. 53 North ☑ or South ☐
Rge. 3 East ☐ or West ☑
Sec. 24, ____ 1/4 SW 1/4 NW 1/4
10 acres 40 acres 160 acres
Gov't Lot ____ County Kootenai
Address of Well Site North of Parks Rd near Caravelle Rd City Athol
(Give at least name of road + Distance to Road or Landmark)
Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	9 Sacks	over bore - 10"

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) ____
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+3	441	.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS none
☐ Perforations Method ____
☐ Screens Screen Type ____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
315 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:
SWNW 24 53N 3W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15+	0	420	1 hr.

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
10	0	15	Sand, Gravel, Bolders		X
10	15	20	Sand, Gravel, Cobbles		X
8	20	225	Sand, Gravel, Cobbles		X
↑	225	240	Gravel, Bolders		X
	240	315	Sand, Gravel, Cobbles		X
	315	340	Granite, Blk/wht, Med. Hard	X	
	340	342	Granite, Blk/wht, Fracture	X	
	342	388	Granite, Blk/wht, Med. Hard		X
	388	395	Granite, Rose, Med. Hard		X
	395	410	Granite, Blk/wht, Med. Hard		X
↓	410	416	Granite, Blk/wht, Fractured	X	
8	416	441	Granite, Blk/wht, Med. Hard		X

Completed Depth 441 (Measurable)
Date: Started 5/23/95 Completed 5/25/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Krass Drilling & Pump Serv Firm No. 555
Firm Official ____ Date 6-5-95
and
Supervisor or Operator Anthony Kraut Date 5/26/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES