

**WELL DRILLER'S REPORT
RECEIVED**

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	:	Long
:	:	:

1. WELL TAG NO. D0013867 **NOV 06 2000**

Drilling Permit No:

Other IDWR No.

2. OWNER


Name Ron Carlson

Address PO Box 710

City Veradale State WA Zip 99037

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 50 ☒ North or ☐ South

Rge. 04 ☐ East or ☒ West

Sec. 35 1/4 SE 1/4 NW 1/4

Gov't Lot County KOOTENAI

Lat: : : Long: : :

Address of Well Site Kidd Island Bay

City Coeur d'Alene

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
WELL SEAL				
BENTONITE	0	20	6 bags	overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 26

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2	-26	.250	steel	☒	☐	☒
4	-8	-143	.160	pvc	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method saw cut

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-103	-143	1/8x6	120	4	pvc	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

70 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

50N 4W 35

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
estimate 8		143	1 hour

Water Temp. cold Bottom Hole Temp cold

Water Quality test or comments: good little cloud

Depth first Water encountered 83

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	26	Clayish soils w/gravel	☐	☒
6	26	83	Basalt dark gray	☐	☒
6	83	100	Basalt broken w/H2O apx 3-4 gpm	☒	☐
6	100	138	Basalt dark gray	☐	☒
6	138	143	Basalt broken w/H2O apx 3-5 gpm	☒	☐

Completed Depth 143 (Measurable)

Date: Started 10/30/00 Completed 10/30/00

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date 11-2-00

and Supervisor or Operator Date 10/31/00

(Sign Once if Firm Official and Operator)

Louie Hanner