RECEIVED
OCT 23 2000
IDWR/North

Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by
Twp ___ Rge ___ Sec ___
___ 1/4 ___ 1/4 ___ 1/4
Lat: : : Long: : :

1. WELL TAG NO. D0013920
DRILLING PERMIT N 76708 2
Other IDWR No

POSTED

2. OWNER:
Name John Kelly
Address PO Box 1645
City Coeur d' Alene State ID Zip 83816

3. LOCATION OF WELL by legal description:

N / W / E / S (X)

Twp 53N North ✔ or South
Rge 03W East or West ✔
Sec 03 1/4 SW 1/4 NE 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot ___ County Kootenai
Lat Long

Address of Well Site: (see next line)
7204 E Forest View Drive City Athol
Lot ___ Blk ___ Sub. Name (see next line)

4. USE:
✔ Domestic Municipal Monitor Irrigation
Thermal Injection Other

5. TYPE OF WORK check all that apply (Replacement etc.)
✔ New Well Modify Abandonment Other

6. DRILL METHOD
✔ Air Rotary Cable Mud Rotary Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	Amount Sacks/Lbs	Method
Bentonite	0	18	14 sacks	pour in

Drive Shoe Used? ✔ Y N Shoe Depth(s) Ring Bit
Drive Shoe Seal Tested? Y ✔ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	398	0.250	Steel	✔		✔	

Length Headpipe ___ Length Tailpipe ___

9. PERFORATIONS/SCREENS
✔ Perforations? Method air perforator
Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
375	395	1"	400		Steel	✔	

10. STATIC WATER LEVEL or ARTESIAN PRESSURE
350 ft. below ground. Artesian pressure ___ lb.
Depth flow encountered 350 ft. Describe access port or control devices: Steel cap welded

11. WELL TESTS:
Pump Bailer ✔ Air Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20	100%	390	1 hr.

Water Temp. cold Bottom hole temp. cold
Water Quality test or comments: (below) Depth first Water Encountered 350
slight color, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water Y	Water N
8	0	1	Topsoil		✔
8	1	18	Sand & gravel - 3/4" minus		✔
8	18	180	Sand & gravel - 3/4" minus		✔
8	180	255	Sand & gravel - 1/8" minus		✔
8	255	320	Sand & gravel - 3/4" minus		✔
8	320	400	Sand & gravel - 1/2" minus	✔	

Completed Depth 398 (Measurable)
Date: Started 10/15/00 Completed 10/18/00

13. DRILLERS CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official and Supervisor or Operator Jason C. Beckham Date 10/18/00
Date 10/18/00

FORWARD WHITE COPY TO WATER RESOURCES

350

53N 3W 3