

RECEIVED

Form 238-7

11/9 AUG 24 1999

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

076721

IDWR/North

1. WELL TAG NO. D0010435

DRILLING PERMIT N

95-99-N-127

Other IDWR No

2. OWNER:

Name Oneda Parent

Address 25100 N Edwards RD

City Rathdrum

State ID

Zip 83858

3. LOCATION OF WELL by legal description:

N	Twp	53N	North	☒ or	South	☐
	Rge	04W	East	☐ or	West	☒
	Sec	31	1/4 SW 1/4 NE 1/4			
			10 Ac	40 Ac	160 Ac	
Gov't Lot	County Kootenai					
Lat	Long					

Address of Well Site: (see next line)

41 to Twin Lakes Sportman access go r top of hill City

Lot Blk Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK				Method
Material	From	To	Sacks/Lbs	
Bentonite	0	-18	10 Sacks	Pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s)

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	-458	0.025	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations? Method

☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

365 ft. below ground. Artesian pressure lb.

Depth flow encountered 365 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
7-8	100%	455	1 hr.

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 362
 silty, cloudy, trace of sand

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature	Water
8	0	6	Topsoil	☐ Y ☐ N
8	6	19	Sand & gravel - 3/4 minus	☐ Y ☐ N
6	19	135	Sand & gravel - 3/4 minus	☐ Y ☐ N
6	135	249	Sand & gravel - fine	☐ Y ☐ N
6	249	300	Sand - brown	☐ Y ☐ N
6	300	367	Sand & gravel - 1/2 minus	☐ Y ☐ N
6	367	430	Clay - gray/brown	☐ Y ☐ N
6	430	445	Clay - orange - decomposed granite	☐ Y ☐ N
6	445	458	Granite - black/white/purple - soft	☐ Y ☐ N
6	458	480	Sand - water @470 -	☐ Y ☐ N
			moving some color & fines	☐ Y ☐ N
			Recommend setting pump at the bottom	☐ Y ☐ N
			of casing to develop out sand	☐ Y ☐ N

Completed Depth 470 (Measurable)

Date: Started 8/13/99 Completed 8/16/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 41

Firm Official

Date 8/19/99

Supervisor or Operator Jason C. Beckham

Date 8/19/99

FORWARD WHITE COPY TO WATER RESOURCES

53 N 4 W 31