

RECEIVED

Form 238-7
11/97

JAN 30 2004

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

IDWR/North

RECEIVED

1. WELL TAG NO. D0028643

DRILLING PERMIT N 805918 SEP 04 2003

Other IDWR No

2. OWNER:

IDWR/North

Name Cliff Anderson

Address 5969 S Panorama View Drive

City Harrison

State ID

Zip 83833

3. LOCATION OF WELL by legal description:

N	Twp	49N	North	☒ or	South
	Rge	03W	East	☐ or	West
	Sec	17	1/4 SE	1/4 NW	1/4
			10 Ac	40 Ac	160 Ac
	Gov't Lot		County	Kootenai	
	Lat		Long		

Address of Well Site: (see next line)

Panorama View Drive

City

Lot Blk Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Gran.	0	18	8 Sacks	Pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 142 Ring BitDrive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6"	+3	142	0.250	STEEL	☒		☒	

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations? Method Air Perforator
☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
100	126	1x1/4	200	6"	STEEL	☒	

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

42 ft. below ground. Artesian pressure lb.

Depth flow encountered 80 - 125 ft. Describe access port or

control devices: STEEL CAP WELDED

Office Use Only

Inspected by

Twp Rge Sec

1/4 1/4 1/4

Lat : : Long: : :

11. WELL TESTS:

Pump

Bailer

☒ Air☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
12+	100%	135	1 Hour

Water Temp.

COLD

Bottom hole temp.

COLD

Water Quality test or comments: (below) Depth first Water Encountered 80

CLEAR, COLD, NO SMELL

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
8	0	18	Topsoil & Clay - Brown	☐ Y	☒ N
8	18	80	Basalt - Black - Broken	☐ Y	☒ N
8	80	85	Basalt - Black - Soft -- 3 GPM	☒ Y	☐ N
8	85	126	Basalt - Black - Broken -- 9 GPM	☒ Y	☐ N
8	126	129	Hardpan - Brown	☐ Y	☒ N
8	129	142	Clay - Orange/Brown	☐ Y	☒ N

Completed Depth 142 (Measurable)

Date: Started 8/15/03 Completed 8/18/03

13. DRILLERS CERTIFICATION


I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Firm No 414

Name

Firm Official and



Date 8/19/03

Supervisor or Operator Jason C. Beckham

Date 8/19/03

FORWARD WHITE COPY TO WATER RESOURCES

705

49N 3W 17