

RECEIVED

Form 238-7

11/97

JUL 20 1999

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

076698

Office Use Only
 Inspected by _____
 Twp _____ Rge _____ Sec _____
 1/4 _____ 1/4 _____ 1/4 _____
 Lat: : : Long: : :

IDWR/North

1. WELL TAG NO. D0010337

DRILLING PERMIT N 95-99-N-104

Other IDWR No _____

2. OWNER:

Name Erin Reasor

Address 1516 E 1st

City Post Falls

State ID

Zip 83854

3. LOCATION OF WELL by legal description:

N
 Twp 50N North ☐ or South ☐
 Rge 05W East ☐ or West ☒
 Sec 24 1/4 NW 1/4 SW 1/4
 10 Ac 40 Ac 160 Ac
 Gov't Lot _____ County Kootenai
 Lat _____ Long _____
 S
 Address of Well Site: (see next line)

Top of Greensferry

City

Lot

Blk

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	59	14 sacks	dry pour

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 59'

Drive Shoe Seal Tested? ☐ Y ☐ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	1	59	0.25	steel	☒	☐	☒	☐
4	-10	200	0.16	PVC	☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe

Length Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations? Method Drill

☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
160	200	1/8	500	1/8	PVC	☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

-10 ft. below ground. Artesian pressure lb.

Depth flow encountered 100 ft. Describe access port or

control devices: steel cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
15 gpm	100%	200	1 hr.

Water Temp. cold

Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 100 clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water Y N
8	0	22	Clay - brown	☐ ☐
8	22	59	Decomposed granite	☐ ☐
6	59	97	Decomposed granite - soft	☐ ☐
6	97	127	Broken white quartz	☐ ☐
			7 gpm	☐ ☐
6	127	157	Decomposed granite	☐ ☐
6	157	200	Broken white granite	☐ ☐
			7 to 8 GPM - 180'	☐ ☐

Completed Depth 200 (Measurable)

Date: Started 7/15/99 Completed 7/19/99

13. DRILLERS CERTIFICATION

I/we certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Firm No 4

Name

Firm Official

and

Supervisor or Operator Timothy R. Volking

Date 7-19-99

Date 7/16/99

FORWARD WHITE COPY TO WATER RESOURCES

17

50N 5W 24