

PANHANDLE HEALTH DISTRICT I
INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

PERMIT FEE \$50.00

PERMIT NO. 7508 PAID 7 CASH CHECK NO FEE DATE Sept. 24, 1984
INSTALLATION FOR (NAME) Lester Cooper SIZE OF LOT 10 Acres FT. X FT.
LEGAL DESCRIPTION OF PROPERTY A portion of S4, S4, NE Sec. 17, T 52N, R 3W

LOCATION OF INSTALLATION N. 20160 Rimrock Rd. Ohio Match to Rimrock
Left 1/2 mile on Right

NO. LIVING UNITS 1 BEDROOMS 3 BATHS 2 PEOPLE SERVED 3 OTHER MOBILE HOME

SEPTIC TANK 1,000 GALS. - DISTANCE TO DWELLING FOUNDATION 5' min WELL 50' min WATER LINE 10' min
SURFACE WATER 30' min TYPE OF TANK: CEMENT X METAL OTHER

DISPOSAL AREA: DRAIN FIELD XX ABSORPTION BED OTHER DIMENSIONS 150 linear ft.
COMPONENT SEPARATIONS: SHALLOW - MAX. 2 FT. DEEP

PROPERTY LINE:

FRONT 5' min FT. BACK 5' min FT. SIDE 5' min FT. DWELLING FOUNDATION 20' min FT.
WELL 100' min FT. SURFACE WATER 300' min FT. SEPTIC TANK 6' min FT. NEIGHBOR'S WELL 100' min FT.
DEPTH TO GROUND WATER WATER SERVICE LINES 25' min FT. SPRING

I UNDERSTAND THAT THIS PERMIT IS NON-TRANSFERABLE AND IS VALID FOR 1 YEAR FROM THE DATE OF APPLICATION. DRAINFIELD MUST NOT EXCEED 3 FEET IN DEPTH.

APPLICANT'S SIGNATURE Lester Cooper APPLICANT IS: ☒ OWNER ☐ CONTRACTOR ☐ OTHER

MAILING ADDRESS N 20160 Rimrock Rd PHONE NO.

REMARKS

PERK RATE MIN/In. SOIL PROFILE

PLOT PLAN SUBMITTED 9/21/84 Date 9/21/84 APPROVED Date 9/21/84 DISAPPROVED Date

PERMIT ISSUED BY Martin Marley REMARKS Community Services Approval #12539-9/24/84
Test holes examined early summer.

VICINITY MAP
(Show How To Get There From This Office)

PLOT PLAN
(Show House, Other Buildings, Proposed Sewage Layout, Wells, Water Lines, Roads, Streams, Lakes and Distances Between)

SEE ATTACHED PLOT PLAN

THIS OFFICE MUST BE NOTIFIED FOR FINAL INSPECTION 24 HOURS BEFORE COVERING SYSTEM!

INSPECTION - SYSTEM COVERED APPROVED 9-11-85 NOT APPROVED

INSPECTED BY Don Allen Name INSTALLED BY Lester Cooper Name DATE

REMARKS


SCANNED
JUN 16 2009
SCANNED
JUL 20 2009

TAILED
SITE
PLAN

Name LESTER COOPER
Legal Des. A PORT S 1/2 S 1/2
(17-52-3)
Total Sq. Ft. or Acreage _____
Scale 1" = 20' or 1" = 40'

PLAN
MUST
SHOW

Setbacks & Existing or Proposed
Easements. Location & Dimensions
of Lot Lines, Proposed Buildings,
Roads, Sewage Disposal & Other
Utility Services.



The information shown and the statements I have made are correct.

Applicant Signature _____

Date _____

For Official Use Only

Zoning _____

Permit# _____

Accepted By _____

Reviewed BY

Planning Commission _____

Health Dist. _____

Build. Dept. _____

Assessor _____

NOTE: DETAILED PLANS SHOWING THE SAME INFORMATION MAY BE SUBSTITUTED FOR THIS FORM

SCANNED

JUN 16 2009

SCANNED

JUL 20 2009

BUILDING PERMIT

KOOTENAI CO., IDAHO

Job Address North 20160 Rimrock Road

Legal Description A portion of S1/2, S1/2

NE Section 17-52-3, See application

Owner Lester Cooper Tel. # 772-7941

Address N. 20160 Rimrock Road, Hayden Lake

Contractor Self Tel. # _____

Address _____

LOCATION: Ohio Match to Rimrock Left 1/2 mile on Right.

Plan # _____

Application# Nº 12539

Date Issued 9-24-84

ED Number _____

Permit Fee \$ 50.00

Valuation -0-

Type of Occupancy - Single Resident ()

Multi. Resident (), Commercial ()

Industrial (), Agricultural ()

Other 1979 Kit 14 x 70

Type of Const. - Wood Frame (),

Steel (), Conc. Masonry ()

Reinf Conc (), other Mobile Home
X No Flood Zone

SIZE: _____

ZONING: Rural

Health District Approval _____

Permit # 7508

Date 9-24-84

Not Required _____

CALL FOR INSPECTIONS 664-8237
Lakes Hwy. Dist.

SCANNED

JUN 16 2009

SCANNED

JUL 20 2009

COOPER



SCANNED

JUL 16 2009

SCANNED
JUL 20 2009