

WHITAKER PIN 0-6460-000-003-0



CORRECTED REPORT

Form 238-7
11/97IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____	1/4 _____	1/4 _____	
Lat _____	Long _____		

1. WELL TAG NO. D0022380

DRILLING PERMIT N 778584

Other IDWR No _____

2. OWNER:

Name Pete MontemayorAddress W 960 Prairie AveCity Post FallsState IDZip 83854

3. LOCATION OF WELL by legal description:

N		Twp		51N		North		✓ or		South	
W		Rge		05W		East		or		West	
S		Sec		08		1/4		NE 1/4		SW 1/4	

Gov't Lot _____ County Kootenai 10 Ac 40 Ac 160 Ac

Lat _____ Long _____

Address of Well Site: (see next line)

N Howell Rd to Smith, left on N Paradise Road

City _____

Lot _____

Blk _____

Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	3 sacks	dry pour

Drive Shoe Used? ☒ Y N Shoe Depth(s) 18'Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6"	+2	18	0.250	steel	✓			✓
4"	-10	203	0.160	PVC		✓		

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations? _____ Method _____

Screens? _____ Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
163	203	40		4"	PVC		✓

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

12 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 43' ft. Describe access port orcontrol devices: steel cap welded

11. WELL TESTS:

Pump	Bailer	✓ Air	Flowing Artesian
Yield gal./min.	Drawdown	Pump Level	Time
8 gpm	100%	200	1 hr.

Water Temp. _____ cold Bottom hole temp _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 43
cold, clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature:	Water
8	0	7	Topsoil Sand	Y
8	7	18	Decomposed granite	Y
6	18	67	Decomposed granite - soft	Y
6	67	94	Granite - soft-broken-brown/gray	Y
6	94	135	Granite - gray - soft	Y
6	135	149	Granite - gray - soft	Y
6	149	177	Granite - gray - medium soft	Y
6	177	183	Granite - gray - fractured	Y
6	183	203	Granite - salt/Pepper	Y

Completed Depth 203 (Measurable)
Date: Started 6/11/02 Completed 6/12/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.Firm No 414

Firm Official and _____

Date 6/14/02Supervisor or Operator Mark A. PenickDate 6/14/02

FORWARD WHITE COPY TO WATER RESOURCES

523