

CORRECTED REPORT

RECEIVED

Form 238-JUN 21 2002
11/97

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0022346

DRILLING PERMIT NO. 779130

Other IDWR No.

2. OWNER:

Name John Davis

Address P.O. Box 1190

City Rathdrum State ID Zip 83858

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

Twp. 53 North		Rge. 4 East		Sec. 30	
Gov't Lot		County Kootenai		Long	

Address of Well Site 26895 N. Timber
City Rathdrum

11. WELL TESTS:

11. WELL TESTS:

Yield gal/min Drawdown Pumping Level Time

10 gpm			3 hrs
--------	--	--	-------

Water Temp.

Bottom hole temp.

Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Depth first Water Encounter 42'

Bore	From	To	Remarks: Lithology, Water Quality & Temperature	Water
8	0	2	Silt, sand	
	2	16	Sand, gravel, fine	
	16	29	Silt, sand, gravel	
	29	39	Sand, gravel	
	39	42	Shale, grey, broken	
	42	44	Shale, rose, soft 3 gpm	x
6	44	81	Shale, grey, medium	
	81	87	Shale, grey, rose	
	87	115	Shale, rose w/grey	
	115	138	Shale, grey w/black & white	
	138	142	Shale, grey, rose, hard	
	142	163	Shale, grey, medium 5-7 gpm	x
	163	170	Shale, brown, grey	
	170	186	Shale, grey, rose	
	186	189	Shale, grey, white	
	189	202	Shale, rose, 1 gpm	x
	202	206	Shale, grey	

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT	METHOD
Material: From To Sacks or Pounds		
Bentonite 0 30 250#		dry granular

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 44'

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	44	250	Steel	☒	☐	☐	☐
4"	6	206	160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

XXX Perforations Method saw cut 1/8"x6"

Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
186	206	1/8	45			☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

63 ft below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices:

53N 4W 30

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only
Inspected by
Twp Rge Sec
1/4 1/4 1/4
Lat Long
Flowing Artesian

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name McCarty Drilling & Pump Inc Firm No. 586

Firm Office Date 6-17-02

Driller or Operator Date

(Sign once if Firm Official & Operator)