Form 238-7
1/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

POSTED

1. DRILLING PERMIT NO. 94 - 94 - N-27 -CUU
Other IDWR No.

2. OWNER:
Name ALFRED ROUSE
Address HC 01 BOX 311
City KINGSTON State ID Zip 83839

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 50 North ☒ or South ☐
Rge. 03 East ☒ or West ☐
Sec. 29, 1/4 NE 1/4 SW 1/4 (10 acres / 40 acres / 160 acres)
Gov't Lot ____ County Shoshone

Address of Well Site 9 mi Bumble Bee Bridge just before mi 13 City
Old River Road
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	6 sacks	Crumbles

Was drive shoe used? Y ☒ N ☐
Was drive shoe seal tested? Y ☐ N ☐ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	57'	.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method Torch Cut
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
54	56	1/16	12	6"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
18 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:
NE SW 29 50N 3E

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15			

Water Temp. Cold Bottom hole temp.
Water Quality test or comments: Good

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	2	TOP SOIL BROWN SOFT		X
8	2	18	GRAVELS COARSE SAND BROWN SOFT		X
8	18	25	CLAYS LIGHT BROWN SOFT		X
8	25	33	FINE SANDS LT-BROWN SOFT		X
8	33	57	GRAVELS LITTLE COARSE SANDS		
			LIGHT BROWN SOFT	X	

RECEIVED
JUN 27 1994
IDWR

Completed Depth 57' (Measurable)
Date: Started 6/15/94 Completed 6/15/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE INC Firm No. 448
Firm Official John Wheeler Date 6-21-94
and
Supervisor or Operator Mark L. Lee Date
(Signature if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES 94-7646

SCANNED
DEC 31 2009