

RECEIVED

Form 200-7
3-95

Booth Consulting and
Management Services

JAN 27 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 77666

Use Typewriter or Ballpoint Pen

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

NORTHERN REGION

1. DRILLING PERMIT TAG#D0003552

Other IDWR No. 95-98-N-5

2. OWNER

Name WARNER, EDWARD


Well Number: 651

Address 11700 S CARLIN BAY RD

City HARRISON State ID Zip 83833

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 49 ☒ North or ☐ South

Rge. 03 ☐ East or ☒ West

Sec. 29 1/4 SW 1/4 NW 1/4

Gov't Lot County KOOTENAI

Lat: : Long: :

Address of Well Site SAME AS ABOVE

City HARRISON

(Give at least name of road + Distance to Road or Landmark)

Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	5 SACKS	DRY

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 18

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	-18	.250	STEEL	☒	☐	☒	☐
4	-5	-395	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-360	-400	1/8X6	88	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

80 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
3			

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	3	TOPSOIL	☐	☒
8	3	18	Large Broken Shale	☐	☒
6	18	50	Shale Soft W/Red Clay	☐	☒
6	50	60	Shale Broken	☐	☒
6	60	80	Shale Medium with Tan Clay trace of	☒	☐
6	80	360	Shale Medium With Tan Clay	☐	☒
6	360	380	Shale Medium Small Fractured 2 grm	☒	☐
6	380	400	Shale Medium	☐	☒

Completed Depth 400' (Measurable)

Date: Started 1/12/98 Completed 1/15/98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Date 1/15/98

and Supervisor or Operator Date 1/15/98

(Sign Once if Firm Official and Operator)

(Jim McLeslie)

SWNW 29 49N 3W



PLACE OF USE

WELL