

Van Bussum, Monica

From: Lori Graves [LGraves@spfwater.com]
Sent: Friday, July 09, 2010 11:06 AM
To: Van Bussum, Monica
Subject: 63-33166, -33197, -33198
Attachments: Pump Curve & Photos.pdf

Monica,

Attached are a pump curve and photos of the diversion system for the above claims. Greg Ramp stated that they average 50 gpm. Please let me know if you have any further questions. Thanks Monica.

Lori Graves
Water Rights Specialist
300 E. Mallard, Ste 350
Boise, ID 83706
208.383.4140 x219
fax 208.383.4156
e-mail lgraves@spfwater.com
www.spfwater.com

PERFORMANCE INFORMATION																
Rating	Model	HP	Motor Voltage	NPT Pipe Size		Distance of Pump Above Water	Discharge Pressure PSI (Pounds per Square Inch)									
							10	15	20	25	30	35	40	45	50	
				BEST	FP5182		2	115/230	2"	2"	5 ft.	69	64	59	53	47
10 ft.	67	62	56			50					45	38	30	18	7	
15 ft.	65	60	54			48					42	35	27	13	-	
20 ft.	62	57	52			46					40	32	23	10	-	

Rating	Model	HP	Motor Voltage	NPT		Distance of Pump Above Water	Discharge Pressure PSI (Pounds per Square Inch)									
				Suction	Discharge		10	15	20	25	30	35	40	45	50	
BEST	FP5182	2	115/230	2"	2"	5 ft.	69	64	59	53	47	40	34	24	14	
						10 ft.	67	62	56	50	45	38	30	18	7	
						15 ft.	65	60	54	48	42	35	27	13	-	
						20 ft.	62	57	52	46	40	32	23	10	-	





