

State of Idaho
Department of Water Resources
Adjudication Claim
95-7813

Water Service Area Boundary for Skyview Water Association
May 15, 2009



Legend

-  Point of Diversion
-  Place Of Use Boundary
-  Townships
-  PLS Sections
-  Quarter Quarters

0 0.05 0.1 0.2 Miles



A horizontal scale bar with tick marks at 0, 0.05, 0.1, and 0.2 miles.



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

USE TYPEWRITER OR
BALLPOINT PEN

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name EARL HANSEN
Address RATHDRUM IDA
Owner's Permit No. 95-78-N-52

7. WATER LEVEL

Static water level 246 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ °F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☒ Bailor ☐ Other

Discharge G.P.M.	Drawdown	Hours Pumped
<u>Bailor 20</u>	<u>0</u>	<u>4 hrs</u>
<u>Pump 7.5</u>	<u>0</u>	<u>3 hrs</u>

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal
or Injection

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water Yes
	From	To		
8"	0	5	TOP SOIL AND GRAVEL	
	5	16	GRAVEL AND CLAY	
	16	27	LARGE GRAVEL	
	27	36	PER "	
	36	39	BOULDER	
	39	52	PER GRAVEL	
	52	59	LARGE "	
	59	79	CLAY AND GRAVEL	
	79	90	BOULDER	
	90	159	CLAY AND GRAVEL	
	159	166	BOULDER	
	166	172	CLAY AND GRAVEL	
	172	186	LARGE "	
	186	189	CLAY	
	189	198	BOULDER	
	198	234	CLAY AND LARGE GRAVEL	
	234	246	BOULDER AND CLAY	
	246	290	SAND AND GRAVEL	✓
	290	303	LARGE GRAVEL	✓

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 8 inches Total depth 303 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>304</u> inches	<u>8</u> inches	<u>1</u> feet	<u>283</u> feet
<u>320</u> inches	<u>8</u> inches	<u>283</u> feet	<u>303</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____


Placed from _____ feet to _____ feet

Surface seal depth 19 Material used in seal: ☐ Cement grout
☒ Puddling clay ☐ Well cuttings

Sealing procedure used: ☐ Slurry pit ☒ Temporary surface
casing
☐ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County KOOTENAI

NW ¼ NW ¼ Sec. 33, T. 52 N. R. 4 E. W

10.

Work started 1-15-78 finished 3-15-78

11. DRILLERS CERTIFICATION

Firm Name BRAND X WATER WELLS Firm No. 289

Address RATHDRUM IDA Date 3-9-78

Signed by (Firm Official) Lendon Cordon

and

(Operator) Lendon Cordon