



WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer
within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name Mr. Curtis Payne
Address 22614 S. 4th
Owner's Permit No. APP. For 93-71-N-1

7. WATER LEVEL

Static water level 110 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

AIR Blow Test
☐ Pump ☐ Bailor ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
<u>50 GPM</u>	<u>60</u>	<u>4</u>

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 337 feetCasing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>18</u> feet	<u>160</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet


Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feetGravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal? ☒ Yes ☐ No To what depth 160 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.

County Kootenai
SE 1/4 SW 1/4 Sec. 19, T. 47 N, R. 4 W

10.

Work started July 1-1971 finished July 7-1971

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is
true to the best of my knowledge.Driller's or Firm's Name E.H. Holman Drilling Co. Number 105
Address 1015 Pine St. Spokane, Wn
Signed By [Signature] Date July 7-1971