

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

1. WELL TAG NO. D0022834

Drilling Permit No: 787844
Other IDWR No. _____

2. OWNER


Name TARNASKY, WILLIAM Well Number: 501

Address 1200 ROCK RIDGE LANE

City COEUR D'ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 51 ☒ North or ☐ South
Rge. 4 ☐ East or ☒ West
Sec. 20 1/4 NW 1/4 SE 1/4

Gov't Lot _____ County KOOTENAI

Lat: _____ Long: _____

Address of Well Site HUETTER RD.

City POST FALLS

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☐ Domestic ☐ Municipal ☐ Monitor ☒ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT Sacks or Pounds	METHOD
Material	From	To		
BENTONITE	0	20	10 BAGS	OVERBORE

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) R.B.

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
10	+2	305	.250	STEEL	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☒ Screens Screen Type STAINLESS STEEL

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-305	325	.100		9	SS	☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

251 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 270 ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artes

Yield gal./min.	Drawdown	Pumping Level	Time
100 +			1 HR

Water Temp. COLD Bottom Hole Temp COLD

Water Quality test or comments: CLOUDY

Depth first Water encountered 270

12. LITHOLOGIC LOG:(Describe repairs or abandonm

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y
12	0	3	Top Soil	☐
12	3	20	Gravels & Clay	☐
10	20	97	Gravels	☐
10	97	130	Sand & Gravel	☐
10	130	251	Multi Color Gravels	☐
10	251	325	Multi Color Gravels Water starts @270	☒

RECEIVED

NOV 22 2002

IDWR/North

Completed Depth 325 (Measurable)

Date: Started 11/1/02 Completed 11/8/02

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Jim McLester Date 11-15-02

and _____

Supervisor or Operator Jim McLester Date 11-15-02

(Sign Once if Firm Official and Operator)

51N 4W 20

95-8645

(Jim McLester)

AUG 26 2009