95-11568

OLSON PIN 0-3500-000-127-A

SCANNED
DEC - 3 2009

Form 238-7
11/97

RECEIVED
AUG 15 2002
IDWR/North

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by_____
Twp_____ Rge____Sec_____
____1/4 ____1/4 ____1/4
Lat: : : Long: : :

POSTED

1. WELL TAG NO. D0022570
DRILLING PERMIT N 782362
Other IDWR No

2. OWNER:
Name Lance Olson
Address 2034 East SE Blvd.
City Spokane State WA Zip 99203

3. LOCATION OF WELL by legal description:

N / W / E / S — X

Twp 51N North ✔ or South
Rge 03W East or West ✔
Sec 15 1/4 SW 1/4 NW 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot ____ County Kootenai
Lat ____ Long ____
Address of Well Site: (see next line)
E Side of Hayden Lake to east burly ct City Hayden Lake
Lot ____ Blk ____ Sub. Name (see next line)

4. USE:
✔ Domestic Municipal Monitor Irrigation
Thermal Injection Other

5. TYPE OF WORK check all that apply (Replacement etc.)
✔ New Well Modify Abandonment Other

6. DRILL METHOD
✔ Air Rotary Cable Mud Rotary Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	40	5 Sacks	Pour In

Drive Shoe Used? ✔ Y N Shoe Depth(s) 76
Drive Shoe Seal Tested? Y ✔ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+1	76	0.250	Steel	✔		✔	
4	60	200	0.160	PVC		✔		

Length Headpipe ____ Length Tailpipe ____

9. PERFORATIONS/SCREENS
✔ Perforations? Method
✔ Screens? Screen Type 40' of .020 PVC

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
160	200	.020	2	4	PVC		✔

10. STATIC WATER LEVEL or ARTESIAN PRESSURE
35 ft. below ground. Artesian pressure ____ lb.
Depth flow encountered 110 ft. Describe access port or control devices: Steel Cap Welded

11. WELL TESTS:
Pump Bailer ✔ Air Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
25	100%	199	1 Hour

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: (below) Depth first Water Encountered 110

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water Y	Water N
8	0	10	Clay & Cobbles		✔
8	10	18	Clay & Small Shale Gravel		✔
8	18	38	Decomposed Granite Brown		✔
8	38	76	Granite Soft Brown & White		✔
6	76	92	Brown White Soft W/Quartz Mica		✔
6	92	110	Black & White W/Quartz Mica		✔
6	110	120	Brown Quartz & White Soft 25 gpm	✔	
6	120	200	Black & White W/Quartz & Mica		✔

Completed Depth 200 (Measurable)
Date: Started 8/5/02 Completed 8/5/02

13. DRILLERS CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official and [signature] PHS. Date 8/7/02
Supervisor or Operator Jason C. Beckham Date 8/7/02

51N 3W 15

FORWARD WHITE COPY TO WATER RESOURCES

562

SCANNED
DEC - 3 2009