

RECEIVED

UN 11 2002

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

DWR/North

TAG NO. D0022269

PERMIT N

778726

R No

ER:

rry Alme

261 S Carpenter

alls ID

State ID

Zip 83854

LOCATION OF WELL by legal description:

N Twp 50N North ☒ or South
Rge 05W East or West ☒
Sec 18 1/4 NW 1/4 SE 1/4
Gov't Lot County Kootenai
Lat Long

S

Address of Well Site: (see next line)

allsap on S Carpenter Loop

City

Blk

Sub. Name (see next line)

estic Municipal Monitor Irrigation

nal Injection Other

TYPE OF WORK check all that apply (Replacement etc.)

Well Modify Abandonment Other

METHOD

otary Cable Mud Rotary Other

NG PROCEDURES

AL/FILTER PACK			Amount	Method
From	To	Sacks/Lbs		
0	22	3 sacks		dry pour

Used? ☒ Y N Shoe Depth(s) 22

Seal Tested? Y ☒ N How?

IG/LINER

om	To	Gauge	Material	Casng	Liner	Weld	Thrded
1	22	0.250	Steel	☒		☒	
5	280	0.165	PVC		☒		

dpipe Length Tailpipe

ORATIONS/SCREENS

ons? Method Drill

? Screen Type

To	Slot	Nmbr	Diam	Material	Casng	Liner
250	3/8"	300	3/8"	PVC		☒

IC WATER LEVEL or ARTESIAN PRESSURE

below ground: Artesian pressure lb.

encountered 137 ft. Describe access port or

ices: Steel cap welded

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4	1/4	1/4	
Lat: : :	Long: : :		

11. WELL TESTS:

Pump	Bailer	☒ Air	Flowing Artesian
Yield gal./min.	Drawdown	Pump Level	Time
12	100%	279	2 hrs

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 137
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water
8	0	19	Decomposed granite - brown/white - soft	☒ Y ☒ N
8	19	22	Granite - brown/white - medium	☒ Y ☒ N
6	22	27	Granite - brown/white - hard	☒ Y ☒ N
6	27	70	Granite - brown/white - soft	☒ Y ☒ N
6	70	80	Granite - brown/white with purple seams	☒ Y ☒ N
6	80	113	Granite - purple/black/white - medium	☒ Y ☒ N
6	113	117	Granite - purple/black/white - very broken	☒ Y ☒ N
6	117	133	Granite - purple/black/white - medium	☒ Y ☒ N
6	133	137	Granite - black/white - broken 12 gpm	☒ Y ☒ N
6	137	168	Granite - purple/black/white	☒ Y ☒ N
6	168	200	Granite - green/white/black - soft	☒ Y ☒ N
6	200	257	Granite - purple/black/white - soft	☒ Y ☒ N
6	257	263	Granite - green/white/black - soft	☒ Y ☒ N
6	263	280	Granite - purple/black/white - medium	☒ Y ☒ N

Completed Depth 280 (Measurable)
Date: Started 5/8/02 Completed 5/9/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official *Jason C. Beckham* Date 5/9/02
Supervisor or Operator Jason C. Beckham Date 5/9/02

FORWARD WHITE COPY TO WATER RESOURCES

0N 5W 18

ALME PIN 50N05W-18-8900

